

COOLANT REPORT


Area

THUNDER SPIRIT [200009532] 27WEA84030 - CONVERTER (S/N EWP01508)

Component Coolant

Fluid

INTERCOOL ETHYLENE GLYCOL (--- QTS)





DIAGNOSIS

Recommendation

The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition


Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

			Apr2022	Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX014481	NX011208	
Sample Date		Client Info		13 Mar 2024	07 Apr 2022	
Machine Age	hrs	Client Info		49200	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
PHYSICAL TEST R	RESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.076	1.079	
Н	Scale 0-14	ASTM D1287		8.69	7.89	
Vitrites	ppm	AP-053:2009		712	600	
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		56.4	59.4	
Freezing Point	°F	ASTM D3321		-50	-56	
Total Dissolved Solids				289.5	325.0	
Carboxylate				n/a	n/a	
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130		14	18	
Phosphorus	ppm	ASTM D6130		1042	1110	
Boron	ppm	ASTM D6130		227	433	
Molybdenum	ppm	ASTM D6130		97	<1	
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	8	0	
Aluminum	ppm	ASTM D6130	>10	<1	0	
Copper	ppm	ASTM D6130	>10	0	<1	
Lead	ppm	ASTM D6130	>10	0	0	
Tin	ppm	ASTM D6130	>10	0	0	
Zinc	ppm	ASTM D6130		0	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		17	0	
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		495	341	
Potassium	ppm	ASTM D6130		4010	2384	
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130	>100	0	0	
Magnesium	ppm	ASTM D6130	>40	0	2	
Hardness	mg/L CaCO3	*In-house	<75	0		



COOLANT REPORT









Certificate 12367

Laboratory Sample No.

: NX014481 Lab Number : 06135982 Unique Number : 10955447

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested**

: 05 Apr 2024 Diagnosed : 05 Apr 2024 - Jonathan Hester

: 01 Apr 2024

NORDEX USA - Chicago 300 SOUTH WACKER DRIVE, SUITE 1500 CHICAGO, IL

Contact: DEVIN LINEHAN DLinehan@nordex-online.com T: (312)386-4124

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : COOL (Additional Tests: GlycolType)

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (312)386-7102

Contact/Location: DEVIN LINEHAN - NORDEX

Report Id: NORDEX [WUSCAR] 06135982 (Generated: 04/05/2024 21:31:33) Rev: 1

US 60606