

COOLANT REPORT

I

Magnesium

Hardness

ppm ASTM D6130 >40

<75

mg/L CaCO3 *In-house

Area THUNDER SPIRIT [200009532] 24WEA84004 (S/N 45541) Component Coolant

Fluid INTERCOOL ETHYLENE GLYCOL (--- QTS)

Recommendation

The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.



SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX014482	NX010583	
Sample Date		Client Info		19 Mar 2024	26 Apr 2022	
Machine Age	hrs	Client Info		60652	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.073	1.070	
pН	Scale 0-14	ASTM D1287		7.84	8.00	
Nitrites	ppm	AP-053:2009		788	148	
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		54.5	52.4	
Freezing Point	°F	ASTM D3321		-45	-40	
Total Dissolved Solids				224.5	69.5	
Carboxylate				n/a	n/a	
CORROSION INHI	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130		9	11	
Phosphorus	ppm	ASTM D6130		1012	121	
Boron	ppm	ASTM D6130		195	86	
Molybdenum	ppm	ASTM D6130		11	10	
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	4	<1	
Aluminum	ppm	ASTM D6130	>10	<1	<1	
Copper	ppm	ASTM D6130	>10	0	<1	
Lead	ppm	ASTM D6130	>10	0	0	
Tin	ppm	ASTM D6130	>10	0	0	
Zinc	ppm	ASTM D6130		0	1	
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		17	0	
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		219	2	
Potassium	ppm	ASTM D6130		3482	743	
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130	>100	0	0	
Manage	1. p			•	0	

0


0


0

Sample Rating Trend



COOLANT REPORT





Unique Number : 10955454 Diagnosed : 05 Apr 2024 - Jonathan Hester Test Package : COOL (Additional Tests: GlycolType) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: NORDEX [WUSCAR] 06135989 (Generated: 04/05/2024 21:32:25) Rev: 1

Contact/Location: DEVIN LINEHAN - NORDEX

T: (312)386-4124

F: (312)386-7102

Contact: DEVIN LINEHAN

DLinehan@nordex-online.com