



OIL ANALYSIS REPORT

Sample Rating Trend

WATER



Area

FP-106 [10024086368]

Machine Id


B23337-1 - AUGER 6 (SE) BIN RAW MATERIAL

Component

Gearbox

Fluid

PETRO CANADA ENDURATEX SYNTHETIC EP 320 (--- QTS)



DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

Wear

All component wear rates are normal.

Contamination

Appearance is milky. There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0907918	WC0872449	WC0820573
Sample Date	Client Info		01 Apr 2024	21 Dec 2023	01 Jul 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	SEVERE	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	81	50	25
Chromium	ppm	ASTM D5185m >15	<1	<1	0
Nickel	ppm	ASTM D5185m >15	<1	<1	<1
Titanium	ppm	ASTM D5185m	<1	<1	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	2	2	1
Lead	ppm	ASTM D5185m >100	<1	<1	0
Copper	ppm	ASTM D5185m >200	1	<1	<1
Tin	ppm	ASTM D5185m >25	1	<1	<1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 33	22	14	12
Barium	ppm	ASTM D5185m 5	0	7	0
Molybdenum	ppm	ASTM D5185m	<1	<1	0
Manganese	ppm	ASTM D5185m	1	<1	<1
Magnesium	ppm	ASTM D5185m 5	2	2	0
Calcium	ppm	ASTM D5185m 5	10	8	1
Phosphorus	ppm	ASTM D5185m 437	456	367	453
Zinc	ppm	ASTM D5185m 5	24	18	<1
Sulfur	ppm	ASTM D5185m 5000	6168	6019	7377

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	2	1	0
Sodium	ppm	ASTM D5185m	8	8	<1
Potassium	ppm	ASTM D5185m >20	11	14	3
Water	%	ASTM D6304 >0.2	▲ 0.649	▲ 1.79	---
ppm Water	ppm	ASTM D6304 >2000	▲ 6490	▲ 17900	---




FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	---	---	▲ 86590
Particles >6µm	ASTM D7647	>5000	---	---	▲ 17562
Particles >14µm	ASTM D7647	>640	---	---	● 828
Particles >21µm	ASTM D7647	>160	---	---	221
Particles >38µm	ASTM D7647	>40	---	---	10
Particles >71µm	ASTM D7647	>10	---	---	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	---	---	▲ 24/21/17

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.7	1.00	1.28	0.77


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ HEAVY	LIGHT
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	● MILKY	● HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	▲ 0.2%	▲ 0.2%	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 323	325	331	320

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0907918 **Received** : 02 Apr 2024
Lab Number : 06136345 **Tested** : 04 Apr 2024
Unique Number : 10955810 **Diagnosed** : 04 Apr 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

HORMEL FOODS - AUSTIN
 1101 NORTH MAIN ST
 AUSTIN, MN
 US 55912
 Contact: RYAN LOWE
 rslowe@hormel.com
 T: (507)437-5674
 F: (507)437-9805

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)