

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

2720517 (S/N 1264) Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
		Client Info		KCPA013479		
Sample Number Sample Date		Client Info		22 Mar 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed	1113	Client Info		Changed		
Sample Status		Oliciti IIIIo		NORMAL		
				HOTHINAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	3		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	13		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	100	14		
Calcium	ppm	ASTM D5185m	0	3		
Phosphorus	ppm	ASTM D5185m	0	12		
Zinc	ppm	ASTM D5185m	0	23		
Sulfur	ppm	ASTM D5185m	23500	22774		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		6		
Potassium	ppm	ASTM D5185m	>20	2		
Water	%	ASTM D6304	>0.05	0.015		
ppm Water	ppm	ASTM D6304	>500	152		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		735		
Particles >6µm		ASTM D7647	>1300	61		
Particles >14µm		ASTM D7647	>80	6		
Particles >21µm		ASTM D7647	>20	2		
Particles >38μm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/13/10		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A = : = ! A (A A !)	I/OII/-	ACTM DODAE	1.0	0.40		

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.42



OIL ANALYSIS REPORT





Certificate 12367

Sample No.

Lab Number : 06136407 $\textbf{Unique Number} \quad : 10955872$

: KCPA013479

Received : 02 Apr 2024 **Tested** Diagnosed

: 04 Apr 2024 - Don Baldridge

: 03 Apr 2024

1025 SHADY OAKS DR DENTON, TX US 76205 Contact: Service Manager

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: Contact/Location: Service Manager - ELIDEN

T: