


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

9166335 (S/N 8488)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

The oil change at the time of sampling has been noted. We recommend you service the filters on this component. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			002023	Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016391	KCPA006486	
Sample Date		Client Info		20 Mar 2024	20 Oct 2023	
Machine Age	hrs	Client Info		4812	1583	
Oil Age	hrs	Client Info		3229	0	
Oil Changed		Client Info		Changed	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	3	
Chromium	ppm	ASTM D5185m	>10	<1	<1	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	3	10	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	8	3	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	<1	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	3	0	
Calcium	ppm	ASTM D5185m	2	4	0	
Phosphorus	ppm	ASTM D5185m		4	39	
Zinc	ppm	ASTM D5185m		14	4	
Sulfur	ppm	ASTM D5185m		19222	439	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	2	4	
Water	%	ASTM D6304	>0.05	<u> </u>	0.006	
ppm Water	ppm	ASTM D6304	>500	2500	69.0	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1270	22852	
Particles >6µm		ASTM D7647	>1300	692	<u>▲</u> 10881	
Particles >14µm		ASTM D7647	>80	<u> </u>	<u></u> 556	
Particles >21µm		ASTM D7647	>20	40	△ 30	
Particles >38μm		ASTM D7647	>4	<u> </u>	2	
Particles >71µm		ASTM D7647	>3	1	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/17/14	<u>22/21/16</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39	0.17	



OIL ANALYSIS REPORT







Certificate 12367

Sample No.

Lab Number

: KCPA016391 : 06136411

Unique Number : 10955876

Received **Tested** Diagnosed

: 09 Apr 2024 - Jonathan Hester Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 09 Apr 2024

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

5103 ELYSIAN FIELDS RD

MARSHALL, TX US 75672

Contact: Service Manager

F: Contact/Location: Service Manager - THUMAR

T: