



# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Area

**WVT**  
Machine Id

**MOBIL Pegasus™ 605 Ultra 40**

Component

**New (Unused) Oil**

Fluid

**MOBIL Pegasus™ 605 Ultra 40 (--- GAL)**

## DIAGNOSIS

### Recommendation

This is a baseline read-out on the submitted sample. ( Customer Sample Comment: This is a new oil sample of the mobile 605 ultra 40 )

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0895557</b>	---	---
Sample Date	Client Info		<b>29 Mar 2024</b>	---	---
Machine Age	hrs	Client Info	<b>0</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed	Client Info		<b>N/A</b>	---	---
Sample Status			<b>NORMAL</b>	---	---

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >45	<b>0</b>	---	---
Chromium	ppm	ASTM D5185m >2	<b>0</b>	---	---
Nickel	ppm	ASTM D5185m >2	<b>0</b>	---	---
Titanium	ppm	ASTM D5185m	<b>0</b>	---	---
Silver	ppm	ASTM D5185m >5	<b>0</b>	---	---
Aluminum	ppm	ASTM D5185m >10	<b>2</b>	---	---
Lead	ppm	ASTM D5185m >5	<b>0</b>	---	---
Copper	ppm	ASTM D5185m >14	<b>0</b>	---	---
Tin	ppm	ASTM D5185m >13	<b>&lt;1</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	---	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	---	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>171</b>	---	---
Barium	ppm	ASTM D5185m	<b>0</b>	---	---
Molybdenum	ppm	ASTM D5185m	<b>0</b>	---	---
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	---	---
Magnesium	ppm	ASTM D5185m	<b>9</b>	---	---
Calcium	ppm	ASTM D5185m	<b>1474</b>	---	---
Phosphorus	ppm	ASTM D5185m	<b>456</b>	---	---
Zinc	ppm	ASTM D5185m	<b>518</b>	---	---
Sulfur	ppm	ASTM D5185m	<b>3854</b>	---	---

## CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >200	<b>4</b>	---	---
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	---	---
Potassium	ppm	ASTM D5185m >20	<b>0</b>	---	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.814</b>	---	---
Base Number (BN)	mg KOH/g	ASTM D2896 5.7	<b>5.27</b>	---	---



# OIL ANALYSIS REPORT










VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	138	126.4	---
Visc @ 100°C	cSt	ASTM D445	15	13.98	---
Viscosity Index (VI)	Scale	ASTM D2270	110	108	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Sample No.** : WC0895557

**Lab Number** : 06136721

**Unique Number** : 10956186

**Test Package** : MOB 2 ( Additional Tests: FT-IR, KV100, TBN, VI )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**Received** : 02 Apr 2024

**Tested** : 05 Apr 2024

**Diagnosed** : 05 Apr 2024 - Doug Bogart

**EDL NA Recips-Watervliet**

Watervliet Powerstation, 3563 Hennessey Road

Watervliet, MI

US 49098

Contact: Scott Eastman

scott.eastman@edlenergy.com

T:

F: