

## FUEL REPORT

Sample Number

Sample Date

Machine Age

Sample Status

Specific Gravity

Fuel Color

ASTM Color

Visc @ 40°C

**Cloud Point** 

Pour Point

Sulfur (UVF)

Sulfur

Pensky-Martens Flash Point

### Area [25217] GWV HOSPITAL TANK 2 (S/N 182326)

**Diesel Fuel** Fluid

No.2 DIESEL FUEL (LOW-SULPHUR) (5000 GAL)

### DIAGNOSIS

#### Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

### Corrosion


All metal levels are normal indicating no corrosion in the system.

#### Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel.

#### **Fuel Condition**

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.




DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	165	166	
5% Distillation Point	°C	ASTM D86		186	188	
10% Distill Point	°C	ASTM D86	201	195	196	
15% Distillation Point	°C	ASTM D86		203	203	
20% Distill Point	°C	ASTM D86	216	211	210	
30% Distill Point	°C	ASTM D86	230	225	223	
40% Distill Point	°C	ASTM D86	243	239	237	
50% Distill Point	°C	ASTM D86	255	253	252	
60% Distill Point	°C	ASTM D86	267	267	266	
70% Distill Point	°C	ASTM D86	280	284	283	
80% Distill Point	°C	ASTM D86	295	301	301	
85% Distillation Point	°C	ASTM D86		312	311	
90% Distill Point	°C	ASTM D86	310	324	324	
95% Distillation Point	°C	ASTM D86		342	341	
Final Boiling Point	°C	ASTM D86	341	351	351	
Distillation Residue	%	ASTM D86	3.0	1.4	1.4	
Distillation Loss	%	ASTM D86	3.0	0.7	0.6	


IGNITION QUALITY	method				history2
API Gravity	ASTM D7777	37.7	37.6	37.8	
Cetane Index	ASTM D4737	<40.0	47.8	48.2	

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	
Sodium	ppm	ASTM D5185m	<0.1	<1	0	
Potassium	ppm	ASTM D5185m	<0.1	0	1	
Water	%	ASTM D6304	< 0.05	0.004	0.003	
ppm Water	ppm	ASTM D6304	<500	42	32.0	
% Gasoline	%	*In-House	<0.50	0.0	0.0	
% Biodiesel	%	*In-House	<20.0	0.0	0.0	



# **FUEL REPORT**







FLUID CLEANLI	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	571	8458	
Particles >6µm		ASTM D7647	>640	192	2632	
Particles >14µm		ASTM D7647	>80	22	285	
Particles >21µm		ASTM D7647	>20	6	86	
Particles >38µm		ASTM D7647	>4	0	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>18/16/13	16/15/12	20/19/15	
HEAVY METALS	;	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	1	
Nickel	ppm	ASTM D5185m	<0.1	0	0	
Lead	ppm	ASTM D5185m	<0.1	0	<1	
Vanadium	ppm	ASTM D5185m	<0.1	0	0	
Iron	ppm	ASTM D5185m	<0.1	0	0	
Calcium	ppm	ASTM D5185m	<0.1	0	2	
Magnesium	ppm	ASTM D5185m	<0.1	0	<1	
Phosphorus	ppm	ASTM D5185m	<0.1	0	0	
Zinc	ppm	ASTM D5185m	<0.1	0	0	
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						no image
Bottom						no image

Aar77/17/

Mar22/24





Pensky-Martens Flash Point (°C)



Feb 1

Ωk

**CURTIS ENGINE** Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 : DCDF02603 Sample No. Received : 02 Apr 2024 3915 BENSON AVE Lab Number : 06136728 Tested : 12 Apr 2024 BALTIMORE, MD : 12 Apr 2024 - Doug Bogart Unique Number : 10956193 Diagnosed US 21227 Test Package : DF-3 (Additional Tests: Fuel, Screen) Contact: CHARNETTE WATERS Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. CWATERS@CURTISPS.COM \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (410)536-2098

Report Id: CURBAL [WUSCAR] 06136728 (Generated: 04/12/2024 17:57:19) Rev: 1

Contact/Location: CHARNETTE WATERS - CURBAL

Page 2 of 2