




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id

8164845 (S/N 1187)

Component

Compressor

Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|----------|
| Sample Number | Client Info | | | KC130484 | KCP53673 | --- |
| Sample Date | Client Info | | | 26 Mar 2024 | 26 Apr 2023 | --- |
| Machine Age | hrs | Client Info | | 14865 | 9471 | --- |
| Oil Age | hrs | Client Info | | 5000 | 4100 | --- |
| Oil Changed | Client Info | | | Not Chngd | Changed | --- |
| Sample Status | | | | ABNORMAL | NORMAL | --- |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m | >50 | 0 | 0 | --- |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | --- |
| Nickel | ppm | ASTM D5185m | >3 | 0 | <1 | --- |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | --- |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | --- |
| Aluminum | ppm | ASTM D5185m | >10 | <1 | 0 | --- |
| Lead | ppm | ASTM D5185m | >10 | 0 | 0 | --- |
| Copper | ppm | ASTM D5185m | >50 | 4 | 6 | --- |
| Tin | ppm | ASTM D5185m | >10 | 1 | 0 | --- |
| Vanadium | ppm | ASTM D5185m | | <1 | 0 | --- |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | --- |






| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|----------|----------|----------|
| Boron | ppm | ASTM D5185m | | 0 | 0 | --- |
| Barium | ppm | ASTM D5185m | 90 | 0 | 0 | --- |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | --- |
| Manganese | ppm | ASTM D5185m | | 0 | <1 | --- |
| Magnesium | ppm | ASTM D5185m | 90 | 2 | 2 | --- |
| Calcium | ppm | ASTM D5185m | 2 | 0 | 0 | --- |
| Phosphorus | ppm | ASTM D5185m | | 4 | 3 | --- |
| Zinc | ppm | ASTM D5185m | | 0 | 0 | --- |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m | >25 | <1 | 0 | --- |
| Sodium | ppm | ASTM D5185m | | 2 | <1 | --- |
| Potassium | ppm | ASTM D5185m | >20 | <1 | <1 | --- |
| Water | % | ASTM D6304 | >0.05 | 0.007 | 0.005 | --- |
| ppm Water | ppm | ASTM D6304 | >500 | 73 | 58.4 | --- |

| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
|-------------------|--|--------------|------------|-------------------|----------|----------|
| Particles >4µm | | ASTM D7647 | | 11437 | 5802 | --- |
| Particles >6µm | | ASTM D7647 | >1300 | ▲ 2996 | 1131 | --- |
| Particles >14µm | | ASTM D7647 | >80 | ▲ 136 | 61 | --- |
| Particles >21µm | | ASTM D7647 | >20 | ▲ 24 | 20 | --- |
| Particles >38µm | | ASTM D7647 | >4 | 0 | 1 | --- |
| Particles >71µm | | ASTM D7647 | >3 | 0 | 0 | --- |
| Oil Cleanliness | | ISO 4406 (c) | >--/17/13 | ▲ 21/19/14 | 20/17/13 | --- |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | 0.47 | 0.39 | --- |


OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | --- |
| Yellow Metal | scalar | *Visual | NONE | NONE | --- |
| Precipitate | scalar | *Visual | NONE | NONE | --- |
| Silt | scalar | *Visual | NONE | NONE | --- |
| Debris | scalar | *Visual | NONE | LIGHT | --- |
| Sand/Dirt | scalar | *Visual | NONE | NONE | --- |
| Appearance | scalar | *Visual | NORML | NORML | --- |
| Odor | scalar | *Visual | NORML | NORML | --- |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | --- |
| Free Water | scalar | *Visual | | NEG | --- |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 46 | 45.1 | 44.2 | --- |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC130484
Lab Number : 06136897
Unique Number : 10956362
Test Package : IND 2
Received : 02 Apr 2024
Tested : 03 Apr 2024
Diagnosed : 04 Apr 2024 - Don Baldrige

TRANSCENT TVL LLC PACK
 1308 BLAIR ST
 THOMASVILLE, NC
 US 27360
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)