

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

4855505 (S/N 1877)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Nov201	9 Nov2019	Sep 2023 Ma	n/2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA015926	KCPA002887	KC82670
Sample Date		Client Info		28 Mar 2024	29 Sep 2023	08 Nov 2019
Machine Age	hrs	Client Info		78880	74625	47527
Oil Age	hrs	Client Info		3100	0	0
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	18
Chromium	ppm	ASTM D5185m	>10	0	0	<1
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	2	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	7	<1	12
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m				<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	<1
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	100	0	0	<1
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	77	170	317
Zinc	ppm	ASTM D5185m	0	0	0	12
Sulfur	ppm	ASTM D5185m	23500	14824	258	1124
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		2	0	1
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.05	0.005	0.006	0.042
ppm Water	ppm	ASTM D6304	>500	57	62.8	420
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4431	14816	202224
Particles >6µm		ASTM D7647	>1300	1068	△ 3055	<u>▲</u> 123997
Particles >14µm		ASTM D7647	>80	84	158	△ 6265
Particles >21µm		ASTM D7647	>20	25	32	△ 597
Particles >38µm		ASTM D7647	>4	1	2	9
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/14	2 1/19/14	2 4/20
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06136907 Unique Number : 10956372

: KCPA015926

Received : 02 Apr 2024 **Tested**

: 03 Apr 2024 Diagnosed : 04 Apr 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: MORSIL [WUSCAR] 06136907 (Generated: 04/05/2024 20:39:59) Rev: 1

45 RIBAUD AVE

US 14550

T:

F:

SILVER SPRINGS, NY

Contact: Service Manager