OIL ANALYSIS REPORT

Sample Rating Trend



WEAR

Machine Id
HOWE PUMP OUT (S/N 01061-005-1-01-01)
Component
Refrigeration Compressor
Fluid
USPI 1009-68 SC (--- QTS)

DIAGNOSIS

Recommendation
We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear
The iron level is abnormal.

Contamination
There is a moderate amount of visible silt present in the sample.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**USP0008122**	USP0004630	USP0001404
Sample Date		Client Info		**02 Apr 2024**	03 Jan 2024	08 Oct 2023
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	▲ **61**	37	▲ 31
Chromium	ppm	ASTM D5185m	>2	**0**	<1	0
Nickel	ppm	ASTM D5185m		**0**	<1	0
Titanium	ppm	ASTM D5185m		**0**	<1	0
Silver	ppm	ASTM D5185m	>2	**0**	0	0
Aluminum	ppm	ASTM D5185m	>3	**0**	1	0
Lead	ppm	ASTM D5185m	>2	**2**	3	<1
Copper	ppm	ASTM D5185m	>8	**17**	13	12
Tin	ppm	ASTM D5185m	>4	**5**	3	3
Vanadium	ppm	ASTM D5185m		**<1**	0	0
Cadmium	ppm	ASTM D5185m		**<1**	<1	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	0
Barium	ppm	ASTM D5185m		**0**	0	<1
Molybdenum	ppm	ASTM D5185m		**0**	<1	0
Manganese	ppm	ASTM D5185m		**1**	<1	<1
Magnesium	ppm	ASTM D5185m		**0**	<1	0
Calcium	ppm	ASTM D5185m		**0**	<1	0
Phosphorus	ppm	ASTM D5185m		**0**	0	0
Zinc	ppm	ASTM D5185m		**0**	0	<1
Sulfur	ppm	ASTM D5185m	50	**0**	0	0

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	**1**	1	<1
Sodium	ppm	ASTM D5185m		**1**	0	0
Potassium	ppm	ASTM D5185m	>20	**<1**	<1	<1
Water	%	ASTM D6304	>0.01	**0.002**	0.003	0.003
ppm Water	ppm	ASTM D6304	>100	**17**	28	28.4

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	**---**	▲ 331707	▲ 348570
Particles >6µm		ASTM D7647	>2500	**---**	▲ 184114	▲ 266308
Particles >14µm		ASTM D7647	>320	**---**	▲ 586	▲ 25600
Particles >21µm		ASTM D7647	>80	**---**	36	▲ 965
Particles >38µm		ASTM D7647	>20	**---**	0	0
Particles >71µm		ASTM D7647	>4	**---**	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	**---**	▲ 26/25/16	▲ 26/25/22

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	**0.014**	0.014	0.014

OIL ANALYSIS REPORT









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	▲ **MODER**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	67	**66.6**	66.2	66.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS









Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP0008122
Lab Number : 06136930
Unique Number : 10956395
Test Package : IND 2

Received : 02 Apr 2024
Tested : 04 Apr 2024
Diagnosed : 04 Apr 2024 - Doug Bogart

Certificate L2367

TYSON-COUNCIL BLUFFS-USP

COUNCIL BLUFFS, IA
US
Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: