OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Machine Id
BUSCH 3 BEACH (S/N 15303-USM121040045)
Component
Pump
Fluid
BUSCH R-590 PUMP OIL (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**USPM36619**	USP0002956	USPM28459
Sample Date		Client Info		**02 Apr 2024**	30 Oct 2023	18 Jul 2023
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**NORMAL**	ATTENTION	ATTENTION

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	**2**	<1	<1
Chromium	ppm	ASTM D5185m	>5	**<1**	<1	0
Nickel	ppm	ASTM D5185m	>5	**0**	0	0
Titanium	ppm	ASTM D5185m	>3	**0**	<1	0
Silver	ppm	ASTM D5185m	>3	**0**	0	0
Aluminum	ppm	ASTM D5185m	>7	**2**	0	<1
Lead	ppm	ASTM D5185m	>12	**0**	0	0
Copper	ppm	ASTM D5185m	>30	**1**	2	1
Tin	ppm	ASTM D5185m	>9	**0**	<1	0
Vanadium	ppm	ASTM D5185m		**0**	<1	0
Cadmium	ppm	ASTM D5185m		**0**	<1	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	0
Barium	ppm	ASTM D5185m		**0**	0	0
Molybdenum	ppm	ASTM D5185m		**0**	0	0
Manganese	ppm	ASTM D5185m		**0**	<1	0
Magnesium	ppm	ASTM D5185m		**<1**	0	<1
Calcium	ppm	ASTM D5185m		**3**	0	0
Phosphorus	ppm	ASTM D5185m		**280**	73	69
Zinc	ppm	ASTM D5185m		**0**	0	0
Sulfur	ppm	ASTM D5185m		**182**	249	268

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	**6**	7	8
Sodium	ppm	ASTM D5185m		**0**	2	0
Potassium	ppm	ASTM D5185m	>20	**<1**	1	<1
Water	%	ASTM D6304	>.1	**0.005**	0.001	0.00
ppm Water	ppm	ASTM D6304	>1000	**56**	8.7	0.00

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	**4139**	430	3793
Particles >6µm		ASTM D7647	>1300	**439**	117	813
Particles >14µm		ASTM D7647	>160	**8**	6	46
Particles >21µm		ASTM D7647	>40	**2**	2	9
Particles >38µm		ASTM D7647	>10	**1**	1	0
Particles >71µm		ASTM D7647	>3	**0**	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	**19/16/10**	16/14/10	19/17/13

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		**0.083**	0.092	0.083

OIL ANALYSIS REPORT

Water (KF)



Particle Trend



Water (KF)



Viscosity @ 40°C



Particle Trend



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	120.8	**88.0**	95.9	95.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM36619
Lab Number : 06137458
Unique Number : 10956923
Test Package : IND 2

Received : 03 Apr 2024
Tested : 04 Apr 2024
Diagnosed : 04 Apr 2024 - Doug Bogart

Certificate L2367

CARGILL - TAYLOR PACKING CO

WYALUSING, PA
US 18853
Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: