

OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Machine Id

9335825 (S/N 1047)

Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013756		
Sample Date		Client Info		22 Mar 2024		
Machine Age	hrs	Client Info		3617		
Oil Age	hrs	Client Info		3617		
Oil Changed		Client Info		Changed		
Sample Status				ATTENTION		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	2		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	3		
Calcium	ppm	ASTM D5185m	2	3		
Phosphorus	ppm	ASTM D5185m		51		
Zinc	ppm	ASTM D5185m		5		
Sulfur	ppm	ASTM D5185m		704		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	1		
Water	%	ASTM D6304	>0.05	0.002		
ppm Water	ppm	ASTM D6304	>500	19		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4542		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	110		
Particles >21µm		ASTM D7647	>20	27		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	— 19/18/14		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.13		
. ,	- 5					

Contact/Location: Service Manager - PROJES Page 1 of 2



OIL ANALYSIS REPORT

White Metal scalar 'Visual NONE	history	history1	current	limit/base	method		VISUAL		Particle Trend
Image: state intervent in			NONE	NONE	*Visual	scalar	White Metal		4μm
Image: state intervent in			NONE	NONE	*Visual	scalar	Yellow Metal		
Image: sealar visual NONE NONE Image: sealar visual NONE NONE Image: sealar visual NORML NORML NORML Image: sealar visual NORML NORML NORML NORML NOR			NONE	NONE	*Visual	scalar	Precipitate		3k -
Sandbirk Sudar Visual NORE NORE			NONE	NONE	*Visual	scalar	Silt		?k -
Appearance solar Visual NORML NORML			NONE	NONE	*Visual	scalar	Debris		k -
Water (K5) Odor is scalar 'Visual NORML NORM			NONE	NONE	*Visual	scalar	Sand/Dirt)k
Water (KF) Mater			NORML	NORML	*Visual	scalar	Appearance	22/24	22/24
Water (KF) Free Water scalar Visual NEG Model Imabase current hastory1 Imabase current hastory1 Imabase Model Model Imabase current hastory1 Imabase current hastory1 Imabase Model Model Imabase current hastory1 Imabase Imabase current hastory1 Imabase Imabase current hastory1 Imabase Imabase Imabase current hastory1 Imabase Imabase<			NORML	NORML	*Visual	scalar	Odor	Mar	Mar
Free Water scalar 'Visual NEG Field DPPERTIES method innibase corrent heatory 1 Visc @ 40°C c.St. ASTM D445 46 46.7 SAMPLE IMAGES method innibase corrent heatory 1 Visc @ 40°C c.St. ASTM D445 46 46.7 SAMPLE IMAGES method innibase corrent heatory 1 Color International Corrent Count of the start of			NEG	>0.05	*Visual	scalar	Emulsified Water		Water (KF)
Add Rumber Add Ru			NEG		*Visual	scalar	Free Water		¹⁰ T
Add Number SAMPLE IMAGES method imtobase current instroy1 instroy1 Add Number Color Imtobase current instroy1 in	history	history1	current	limit/base	method	IES	FLUID PROPERT		
Add Number Color Image no image no Add Number Image no image no <			46.7	46	ASTM D445	cSt	Visc @ 40°C		
Add Number Add Number Nu	history	history1	current	limit/base	method	6	SAMPLE IMAGES		00-
Add Number Add Nu									
Image: Contract of the service register of the	no imag	no image					Color	Mar22/24 -	Mar22/24
Image: Control of the service of th									
Water (KF) Water	no imag	no image					Bottom		0 - Base
Water (KF) Water							GRAPHS		30
Water (KF) Water (KF) Water (KF) Water (KF) Wiscosity @ 40°C Wiscosity @ 40°C			Particle Count				Ferrous Alloys		0
Water (KF) Water			Ī	491,520					0
Water (KF) Wood of the second			-	122,880			o thromium		
Water (KF) Water				00.700			6- Inckel		ar22/2.
Viscosity @ 40°C Viscosity &			†	30,720			2	9 H	M
Viscosity @ 40°C Viscosity @							0		
Viscosity @ 40°C Viscosity @				1.920 a. 1.920			22/24		Savara
Viscosity @ 40°C Viscosity @			1.	Mar des (pe					
Viscosity @ 40°C Viscosity @						s			
Viscosity @ 40°C Viscosity @			· ``	ja 120			8 - copper		
Viscosity @ 40°C Viscosity @							C tin		
Viscosity @ 40°C Viscosity @				30			4		
Viscosity @ 40°C Viscosity @			Berevenal				2	V.	0
Viscosity @ 40°C Viscosity @	\mathbf{i}		Į	*z 2			0	CC~-11	Mar22
Acid Number Acid Acid Number Acid Number				lar22//			lar22//		
Image: Second and Second	38µ 7	4μ 21μ		≥ 0					2
Image: State of the second			Acid Number	~0.50					Abnormal
Image: Second			Base	BH 0.40			50 - 9		8-
Abnormal Image: Constraint of the second				.Ĕ.0.30			Base		6 - Base
Abnormal Image: Constraint of the second				-e 0.20			Abnormal		4
Image: State of the state				P 0.10			40 + 0		Abnormal
Image: Second State Image: Second State<			54	- 0.00					
Image: Second State Image: Second State<			ar22/.	ar22//			ar22/i	4 C C	
Sample No. : KCPA013756 Received : 03 Apr 2024 8331 BRI Lab Number : 06138055 Tested : 04 Apr 2024 JES Unique Number : 10962863 Diagnosed : 05 Apr 2024 - Don Baldridge U Certificate L2367 Test Package : IND 2 (Additional Tests: KF, PrtCount) Contact: Service To discuss this sample report, contact Customer Service at 1-800-237-1369. : 03 Apr 2024 Contact: Service			Z	Z			N	C~-14	Mar2
Unique Number : 10962863 Diagnosed : 05 Apr 2024 - Don Baldridge U Certificate L2367 Test Package : IND 2 (Additional Tests: KF, PrtCount) Contact: Service To discuss this sample report, contact Customer Service at 1-800-237-1369. Contact: Service Contact: Service	DUCTS SUPPO 3331 BRISTOL								
Certificate 12367 Test Package : IND 2 (Additional Tests: KF, PrtCount) Contact: Service To discuss this sample report, contact Customer Service at 1-800-237-1369. Contact: Service Contact: Service	JESSUP,								
To discuss this sample report, contact Customer Service at 1-800-237-1369.	US 20	Contact: C	Baldridge	Apr 2024 - Don					
	. Service Mana	Contact: Se		1					
*- Denotes test methods that are outside of the ISO 17025 scope of accreditation.									

Report Id: PROJES [WUSCAR] 06138055 (Generated: 04/05/2024 19:28:11) Rev: 1

Contact/Location: Service Manager - PROJES