


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SX5 51405088 (S/N 1378)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dec2011	Aug2021	Nov2022 Ma	w2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014851	KCP45842	KCP42960
Sample Date		Client Info		22 Mar 2024	23 Nov 2022	17 Aug 2021
Machine Age	hrs	Client Info		30464	18843	9528
Oil Age	hrs	Client Info		11621	3000	2425
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	NORMAL	SEVERE
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	1 13
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	<1
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	24	27	22
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	100	3	0	0
Calcium	ppm	ASTM D5185m	0	3	0	0
Phosphorus	ppm	ASTM D5185m	0	0	6	15
Zinc	ppm	ASTM D5185m	0	15	37	60
Sulfur	ppm	ASTM D5185m	23500	17977	20068	18987
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	8
Sodium	ppm	ASTM D5185m		<1	2	0
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.05	0.005	0.011	△ 0.909
ppm Water	ppm	ASTM D6304	>500	52	117.4	4 9090
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		12457	2178	
Particles >6µm		ASTM D7647	>1300	<u>▲</u> 5652	569	
Particles >14μm		ASTM D7647	>80	1 016	28	
Particles >21µm		ASTM D7647	>20	<u>▲</u> 375	4	
Particles >38µm		ASTM D7647	>4	<u> </u>	0	
Particles >71µm		ASTM D7647	>3	1	0	
Oil Cleanliness		ISO 4406 (c)	>17/13	<u>^</u> 20/17	16/12	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Laboratory Sample No.

: KCPA014851 : 06138058 Lab Number

Unique Number : 10962866

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 03 Apr 2024 **Tested**

: 04 Apr 2024 Diagnosed

: 05 Apr 2024 - Don Baldridge

COLUMBIA, MD Contact: Service Manager

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - PEPCOL

US 21046

T:

F:

6751 ALEXANDER BELL DR