




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
KAESER AS 30T 6595598 (S/N 1235)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

| method | limit/base | current | history1 | history2 |
|---------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | KCPA013048 | KC102238 | KC90987 |
| Sample Date | Client Info | 07 Mar 2024 | 15 Jun 2022 | 07 Oct 2020 |
| Machine Age | hrs | 17827 | 11259 | 6800 |
| Oil Age | hrs | 0 | 4459 | 3307 |
| Oil Changed | Client Info | Changed | Not Changd | Changed |
| Sample Status | | ABNORMAL | ABNORMAL | NORMAL |

WEAR METALS

| method | limit/base | current | history1 | history2 | |
|----------|------------|-----------------|--------------|----------|----|
| Iron | ppm | ASTM D5185m >50 | 3 | 1 | 0 |
| Chromium | ppm | ASTM D5185m >10 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >3 | <1 | 0 | 0 |
| Titanium | ppm | ASTM D5185m >3 | <1 | 0 | 0 |
| Silver | ppm | ASTM D5185m >2 | 0 | <1 | <1 |
| Aluminum | ppm | ASTM D5185m >10 | 2 | 0 | 0 |
| Lead | ppm | ASTM D5185m >10 | <1 | 0 | 0 |
| Copper | ppm | ASTM D5185m >50 | 20 | 24 | 11 |
| Tin | ppm | ASTM D5185m >10 | <1 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | --- | --- | 0 |
| Vanadium | ppm | ASTM D5185m | <1 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | <1 | 0 | 0 |

ADDITIVES

| method | limit/base | current | history1 | history2 | |
|------------|------------|----------------|--------------|----------|-------|
| Boron | ppm | ASTM D5185m | 0 | 1 | 0 |
| Barium | ppm | ASTM D5185m 90 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | <1 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | <1 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m 90 | <1 | 0 | 0 |
| Calcium | ppm | ASTM D5185m 2 | 3 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | 12 | 3 | 8 |
| Zinc | ppm | ASTM D5185m | 5 | 0 | 0 |
| Sulfur | ppm | ASTM D5185m | 15801 | 14172 | 15748 |

CONTAMINANTS

| method | limit/base | current | history1 | history2 | |
|-----------|------------|------------------|--------------|----------|-------|
| Silicon | ppm | ASTM D5185m >25 | <1 | <1 | 0 |
| Sodium | ppm | ASTM D5185m | <1 | <1 | 0 |
| Potassium | ppm | ASTM D5185m >20 | <1 | 0 | 0 |
| Water | % | ASTM D6304 >0.05 | 0.006 | ▲ 0.455 | 0.006 |
| ppm Water | ppm | ASTM D6304 >500 | 68 | ▲ 4550 | 69.0 |






FLUID CLEANLINESS

| method | limit/base | current | history1 | history2 |
|-----------------|------------------------|-------------------|----------|----------|
| Particles >4µm | ASTM D7647 | 124939 | --- | 4197 |
| Particles >6µm | ASTM D7647 >1300 | ▲ 56578 | --- | 1135 |
| Particles >14µm | ASTM D7647 >80 | ▲ 3495 | --- | 60 |
| Particles >21µm | ASTM D7647 >20 | ▲ 671 | --- | 19 |
| Particles >38µm | ASTM D7647 >4 | ▲ 7 | --- | 3 |
| Particles >71µm | ASTM D7647 >3 | 0 | --- | 0 |
| Oil Cleanliness | ISO 4406 (c) >--/17/13 | ▲ 24/23/19 | --- | 17/13 |

FLUID DEGRADATION

| method | limit/base | current | history1 | history2 | |
|------------------|------------|----------------|--------------|----------|-------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 0.4 | 0.312 | 0.28 | 0.361 |


OIL ANALYSIS REPORT







| PARAMETER | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|--------------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | LIGHT | ▲ MODER |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | ● HAZY |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | ▲ 0.2% |
| Free Water | scalar | *Visual | | NEG | ▲ 1.0 |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|-------------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 46 | 45.0 | 45.4 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA013048
Lab Number : 06138066
Unique Number : 10962874
Test Package : IND 2 (Additional Tests: KF, PrtCount)
Received : 03 Apr 2024
Tested : 04 Apr 2024
Diagnosed : 05 Apr 2024 - Don Baldrige

BEMD CO - RBC BEARINGS
 1376 AIRPORT DR
 BALL GROUND, GA
 US 30107
 Contact: T. WHITLEY
 twhitley@rbcbearings.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)