

Area

FUEL REPORT

Sample Rating Trend

WATER

ILNR B2B CUMMINS] C-2-D Component Bulk Tank Diesel Fuel Fluid DIESEL FUEL No. 2 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

Free water present. Moderate concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0914201		
Sample Date		Client Info		27 Mar 2024		
Machine Age	hrs	Client Info		0		
Sample Status				ABNORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445	4.1	2.46		
Pensky-Martens Flash Point	°C	*PMCC Calculated		61.4		
SULFUR CONTER	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0		
Sulfur (UVF)	ppm	ASTM D5453		9		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		172		
5% Distillation Point	°C	ASTM D86		194		
10% Distill Point	°C	ASTM D86		204		
15% Distillation Point	°C	ASTM D86		212		
20% Distill Point	°C	ASTM D86		219		
30% Distill Point	°C	ASTM D86		234		
40% Distill Point	°C	ASTM D86		247		
50% Distill Point	°C	ASTM D86		260		
60% Distill Point	°C	ASTM D86		274		
70% Distill Point	°C	ASTM D86		288		
80% Distill Point	°C	ASTM D86		303		
85% Distillation Point	°C	ASTM D86		314		
90% Distill Point	°C	ASTM D86		325		
95% Distillation Point	°C	ASTM D86		343		
Final Boiling Point	°C	ASTM D86		357		
IGNITION QUALIT	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		37		
Cetane Index		ASTM D4737	<40.0	49		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	<0.05	0.008		
ppm Water	ppm	ASTM D6304	<500	86		
% Gasoline	%	*In-House	<0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		
MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	WC-Method	>=100000	0		
Yeast	CFU/ml	WC-Method	>=100000	0		
Mold	Colonies	WC-Method	MODER			



FUEL REPORT

Water (KF)
Severe
1
Abnormal
/24
Mar27/24 Mar27/24
2 2








HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0		
Nickel	ppm	ASTM D5185m	<0.1	0		
Lead	ppm	ASTM D5185m	<0.1	0		
Vanadium	ppm	ASTM D5185m	<0.1	0		
Iron	ppm	ASTM D5185m	<0.1	0		
Calcium	ppm	ASTM D5185m	<0.1	0		
Magnesium	ppm	ASTM D5185m	<0.1	0		
Phosphorus	ppm	ASTM D5185m	<0.1	0		
Zinc	ppm	ASTM D5185m	<0.1	0		
SAMPLE IMAGES		method	limit/base	current	history1	history2











Contact/Location: SERVICE ? - VITAPE

Page 2 of 2