FUEL REPORT

Sample Rating Trend

WATER

Area
[LNR B2B CUMMINS]
Machine Id
C-2-B
Component
Bulk Tank Diesel Fuel
Fluid
DIESEL FUEL No. 2 (--- GAL)

DIAGNOSIS

Recommendation
We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Corrosion
All metal levels are normal indicating no corrosion in the system.

Contaminants
Free water present. Moderate concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample.

Fuel Condition
Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0914199**	---	---
Sample Date		Client Info		**27 Mar 2024**	---	---
Machine Age	hrs	Client Info		**0**	---	---
Sample Status				**ABNORMAL**	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen		**Red**	---	---
ASTM Color	scalar	*ASTM D1500		**L4.0**	---	---
Visc @ 40°C	cSt	ASTM D445	4.1	**2.42**	---	---
Pensky-Martens Flash Point	°C	*PMCC Calculated		**61**	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		**0**	---	---
Sulfur (UVF)	ppm	ASTM D5453		**9**	---	---

DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		**172**	---	---
5% Distillation Point	°C	ASTM D86		**194**	---	---
10% Distill Point	°C	ASTM D86		**204**	---	---
15% Distillation Point	°C	ASTM D86		**211**	---	---
20% Distill Point	°C	ASTM D86		**219**	---	---
30% Distill Point	°C	ASTM D86		**233**	---	---
40% Distill Point	°C	ASTM D86		**247**	---	---
50% Distill Point	°C	ASTM D86		**260**	---	---
60% Distill Point	°C	ASTM D86		**274**	---	---
70% Distill Point	°C	ASTM D86		**288**	---	---
80% Distill Point	°C	ASTM D86		**303**	---	---
85% Distillation Point	°C	ASTM D86		**314**	---	---
90% Distill Point	°C	ASTM D86		**325**	---	---
95% Distillation Point	°C	ASTM D86		**343**	---	---
Final Boiling Point	°C	ASTM D86		**358**	---	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		**37**	---	---
Cetane Index		ASTM D4737	<40.0	**48**	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	**0**	---	---
Sodium	ppm	ASTM D5185m	<0.1	**1**	---	---
Potassium	ppm	ASTM D5185m	<0.1	**0**	---	---
Water	%	ASTM D6304	<0.05	**0.006**	---	---
ppm Water	ppm	ASTM D6304	<500	**63**	---	---
% Gasoline	%	*In-House	<0.50	**0.0**	---	---
% Biodiesel	%	*In-House	<20.0	**0.0**	---	---

MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	WC-Method	>=100000	**0**	---	---
Yeast	CFU/ml	WC-Method	>=100000	**0**	---	---
Mold	Colonies	WC-Method	MODER	**---**	---	---

FUEL REPORT

Water (KF)



Viscosity @ 40°C



Gas Chromatography (GCD)



Gas Chromatography (GCD)



HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	**0**	---	---
Nickel	ppm	ASTM D5185m	<0.1	**0**	---	---
Lead	ppm	ASTM D5185m	<0.1	**0**	---	---
Vanadium	ppm	ASTM D5185m	<0.1	**0**	---	---
Iron	ppm	ASTM D5185m	<0.1	**0**	---	---
Calcium	ppm	ASTM D5185m	<0.1	**0**	---	---
Magnesium	ppm	ASTM D5185m	<0.1	**0**	---	---
Phosphorus	ppm	ASTM D5185m	<0.1	**0**	---	---
Zinc	ppm	ASTM D5185m	<0.1	**0**	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				*no image*	*no image*
Bottom				*no image*	*no image*

GRAPHS

Fuel Distillation Curve



Pensky-Martens Flash Point (°C)



GCD Spectrum



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0914199 **Received** : 03 Apr 2024
Lab Number : 06138210 **Tested** : 15 Apr 2024
Unique Number : 10963018 **Diagnosed** : 15 Apr 2024 - Doug Bogart
Test Package : DF-2 (Additional Tests: Bacteria, Fuel, Screen)

Certificate L2367

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

VITAL FUEL SYSTEMS
1076 CLASSIC RD
APEX, NC
US 27539
Contact: SERVICE
service@vitalfuelsystems.com
T: (919)629-8180
F: (919)303-7399

Report Id: VITAPE [WUSCAR] 06138210 (Generated: 04/15/2024 21:54:48) Rev: 1

Contact/Location: SERVICE ? - VITAPE