



# PROBLEM SUMMARY

Sample Rating Trend




WATER



Machine Id  
**GAF BEAST T-1 (S/N D-4229)**  
Component  
**Turbine**  
Fluid  
**MOBIL VG 68 (1 GAL)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	---	---
Water	%	ASTM D6304	>0.03	▲ <b>0.106</b>	---	---
ppm Water	ppm	ASTM D6304	>300	▲ <b>1060</b>	---	---
Debris	scalar	*Visual	NONE	▲ <b>MODER</b>	---	---
Emulsified Water	scalar	*Visual	>0.03	▲ <b>0.2%</b>	---	---
Free Water	scalar	*Visual		▲ <b>&gt;10%</b>	---	---

Customer Id: ENEFAR  
Sample No.: WC0713665  
Lab Number: 06138536  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS



# OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id

## GAF BEAST T-1 (S/N D-4229)

Component

Turbine

Fluid

MOBIL VG 68 (1 GAL)

### DIAGNOSIS

#### ▲ Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

Appearance is unacceptable Excessive free water present. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0713665	---	---
Sample Date	Client Info		22 Mar 2024	---	---
Machine Age	hrs	Client Info	3600	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			SEVERE	---	---

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >15	10	---	---
Chromium	ppm	ASTM D5185m >4	<1	---	---
Nickel	ppm	ASTM D5185m >2	0	---	---
Titanium	ppm	ASTM D5185m	<1	---	---
Silver	ppm	ASTM D5185m	0	---	---
Aluminum	ppm	ASTM D5185m >10	2	---	---
Lead	ppm	ASTM D5185m	2	---	---
Copper	ppm	ASTM D5185m >5	7	---	---
Tin	ppm	ASTM D5185m >5	3	---	---
Vanadium	ppm	ASTM D5185m	<1	---	---
Cadmium	ppm	ASTM D5185m	0	---	---

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	---	---
Barium	ppm	ASTM D5185m	0	---	---
Molybdenum	ppm	ASTM D5185m	<1	---	---
Manganese	ppm	ASTM D5185m	0	---	---
Magnesium	ppm	ASTM D5185m	<1	---	---
Calcium	ppm	ASTM D5185m	8	---	---
Phosphorus	ppm	ASTM D5185m	135	---	---
Zinc	ppm	ASTM D5185m	16	---	---
Sulfur	ppm	ASTM D5185m	1259	---	---

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	2	---	---
Sodium	ppm	ASTM D5185m	<1	---	---
Potassium	ppm	ASTM D5185m >20	<1	---	---
Water	%	ASTM D6304 >0.03	▲ 0.106	---	---
ppm Water	ppm	ASTM D6304 >300	▲ 1060	---	---

### INFRA-RED





	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	---	---
Nitration	Abs/cm	*ASTM D7624	2.4	---	---
Sulfation	Abs/.1mm	*ASTM D7415	10.9	---	---

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	2.5	---	---
Acid Number (AN)	mg KOH/g	ASTM D8045	0.12	---	---



# OIL ANALYSIS REPORT







PARAMETER	VISUAL	method	limit/base	current	history1	history2
White Metal	White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	Precipitate	scalar	*Visual	NONE	NONE	---
Silt	Silt	scalar	*Visual	NONE	NONE	---
Debris	Debris	scalar	*Visual	NONE	▲ MODER	---
Sand/Dirt	Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	Appearance	scalar	*Visual	NORML	● HAZY	---
Odor	Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	Emulsified Water	scalar	*Visual	>0.03	▲ 0.2%	---
Free Water	Free Water	scalar	*Visual		▲ >10%	---

PARAMETER	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	67.5	---	---

### SAMPLE IMAGES

PARAMETER	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

### GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0713665 **Received** : 04 Apr 2024  
**Lab Number** : 06138536 **Tested** : 10 Apr 2024  
**Unique Number** : 10963344 **Diagnosed** : 10 Apr 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: FT-IR, KF )

**ENERGY RESOURCES GROUP, INC**  
 23 COMMERCE PARK WAY  
 FARMINGTON, NH  
 US 03835  
 Contact: MIKE MORIN  
 m.morin@energyresourcesgroup.us

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (603)335-2535

F: (603)335-2539