




OIL ANALYSIS REPORT

Sample Rating Trend

WEAR



Area
CHAD STEELE
 Machine Id
22-010S9-1 - 1008H
 Component
Compressor
 Fluid
{not provided} (--- QTS)



DIAGNOSIS

▲ Recommendation

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. Please specify the brand, type, and viscosity of the oil on your next sample.

▲ Wear

The copper level is severe.

▲ Contamination

Elemental level of silicon (Si) above normal indicating ingress of seal material.

▲ Fluid Condition

The AN level is above the recommended limit.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
--------------------	--	--------	------------	---------	----------	----------

Sample Number	Client Info			WC0881566	---	---
Sample Date	Client Info			02 Apr 2024	---	---
Machine Age	mls	Client Info		0	---	---
Oil Age	mls	Client Info		0	---	---
Oil Changed	Client Info			N/A	---	---
Sample Status				SEVERE	---	---

WEAR METALS		method	limit/base	current	history1	history2
-------------	--	--------	------------	---------	----------	----------

Iron	ppm	ASTM D5185m	>50	1	---	---
Chromium	ppm	ASTM D5185m	>5	<1	---	---
Nickel	ppm	ASTM D5185m		1	---	---
Titanium	ppm	ASTM D5185m		<1	---	---
Silver	ppm	ASTM D5185m		0	---	---
Aluminum	ppm	ASTM D5185m	>15	1	---	---
Lead	ppm	ASTM D5185m	>65	0	---	---
Copper	ppm	ASTM D5185m	>65	▲ 3090	---	---
Tin	ppm	ASTM D5185m	>10	<1	---	---
Vanadium	ppm	ASTM D5185m		0	---	---
Cadmium	ppm	ASTM D5185m		<1	---	---

ADDITIVES		method	limit/base	current	history1	history2
-----------	--	--------	------------	---------	----------	----------

Boron	ppm	ASTM D5185m		73	---	---
Barium	ppm	ASTM D5185m		0	---	---
Molybdenum	ppm	ASTM D5185m		<1	---	---
Manganese	ppm	ASTM D5185m		<1	---	---
Magnesium	ppm	ASTM D5185m		2	---	---
Calcium	ppm	ASTM D5185m		456	---	---
Phosphorus	ppm	ASTM D5185m		386	---	---
Zinc	ppm	ASTM D5185m		20	---	---
Sulfur	ppm	ASTM D5185m		897	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
--------------	--	--------	------------	---------	----------	----------






Silicon	ppm	ASTM D5185m	>35	▲ 157	---	---
Sodium	ppm	ASTM D5185m		1	---	---
Potassium	ppm	ASTM D5185m	>20	2	---	---
Water	%	ASTM D6304	>0.1	0.019	---	---
ppm Water	ppm	ASTM D6304	>1000	199	---	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
-------------------	--	--------	------------	---------	----------	----------

Acid Number (AN)	mg KOH/g	ASTM D8045		▲ 4.505	---	---
------------------	----------	------------	--	----------------	-----	-----



OIL ANALYSIS REPORT










VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	24.1	---	---
Visc @ 100°C	cSt	ASTM D445	5.64	---	---
Viscosity Index (VI)	Scale	ASTM D2270	187	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0881566 **Received** : 04 Apr 2024
Lab Number : 06138610 **Tested** : 10 Apr 2024
Unique Number : 10963418 **Diagnosed** : 10 Apr 2024 - Jonathan Hester
Test Package : MOB 2 (Additional Tests: KF, KV100, VI)

BASF - TARRYTOWN
 500 WHITE PLAINS RD
 TARRYTOWN, NY
 US 10591
 Contact: CHAD STEELE
 chad.steele@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (914)785-2166