




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area

[ORD001808]

Machine Id

KAESER AS-25 100920.1 - MULHERN BELTING (S/N 1115)

Component

Compressor

Fluid

KAESER SIGMA (OEM) S-460 (3 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|----------|
| Sample Number | Client Info | | WC0907621 | WC05936253 | --- |
| Sample Date | Client Info | | 27 Mar 2024 | 16 Aug 2023 | --- |
| Machine Age | hrs | Client Info | 41774 | 38506 | --- |
| Oil Age | hrs | Client Info | 4840 | 1572 | --- |
| Oil Changed | Client Info | | Not Chngd | N/A | --- |
| Sample Status | | | NORMAL | NORMAL | --- |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >0.05 | NEG | NEG | --- |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|-----------|----------|----------|
| Iron | ppm | ASTM D5185m >50 | 0 | 0 | --- |
| Chromium | ppm | ASTM D5185m >10 | 0 | 0 | --- |
| Nickel | ppm | ASTM D5185m >3 | 0 | 0 | --- |
| Titanium | ppm | ASTM D5185m >3 | 0 | <1 | --- |
| Silver | ppm | ASTM D5185m >2 | 0 | 0 | --- |
| Aluminum | ppm | ASTM D5185m >10 | 0 | 0 | --- |
| Lead | ppm | ASTM D5185m >10 | 0 | 0 | --- |
| Copper | ppm | ASTM D5185m >50 | 14 | 10 | --- |
| Tin | ppm | ASTM D5185m >10 | 0 | <1 | --- |
| Vanadium | ppm | ASTM D5185m | 0 | <1 | --- |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | --- |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|----------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | 0 | 0 | --- |
| Barium | ppm | ASTM D5185m 90 | 0 | 0 | --- |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | --- |
| Manganese | ppm | ASTM D5185m | 0 | <1 | --- |
| Magnesium | ppm | ASTM D5185m 90 | 0 | 11 | --- |
| Calcium | ppm | ASTM D5185m 2 | 0 | 0 | --- |
| Phosphorus | ppm | ASTM D5185m | 2 | 4 | --- |
| Zinc | ppm | ASTM D5185m | 18 | 23 | --- |
| Sulfur | ppm | ASTM D5185m | 19301 | 21391 | --- |

CONTAMINANTS


| | method | limit/base | current | history1 | history2 |
|-----------|--------|-----------------|----------|----------|----------|
| Silicon | ppm | ASTM D5185m >25 | 2 | 1 | --- |
| Sodium | ppm | ASTM D5185m | 2 | 6 | --- |
| Potassium | ppm | ASTM D5185m >20 | 0 | 0 | --- |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|----------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 0.4 | 0.38 | 0.32 | --- |



OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | --- |
| Yellow Metal | scalar | *Visual | NONE | NONE | --- |
| Precipitate | scalar | *Visual | NONE | NONE | --- |
| Silt | scalar | *Visual | NONE | MODER | --- |
| Debris | scalar | *Visual | NONE | NONE | --- |
| Sand/Dirt | scalar | *Visual | NONE | NONE | --- |
| Appearance | scalar | *Visual | NORML | NORML | --- |
| Odor | scalar | *Visual | NORML | NORML | --- |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | --- |
| Free Water | scalar | *Visual | | NEG | --- |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 | |
|------------------|--------|------------|---------|-------------|----------|-----|
| Visc @ 40°C | cSt | ASTM D445 | 46 | 44.4 | 44.2 | --- |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

| | | | | | | |
|--------|--|--|--|--|--|----------|
| Color | | | | | | no image |
| Bottom | | | | | | no image |

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0907621 **Received** : 04 Apr 2024
Lab Number : **06138637** **Tested** : 05 Apr 2024
Unique Number : 10963445 **Diagnosed** : 06 Apr 2024 - Don Baldrige
Test Package : IND 2

ELEVATED INDUSTRIAL SOLUTIONS
 120 LAWTON AVE.
 MONROE, OH
 US 45050
 Contact: ROBIN PRICHARD
 r.prichard@compressedairtechnologies.com
 T: (513)539-5155
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)