

OIL ANALYSIS REPORT

[1666]

ATLAS COPCO GX11FF ATLAS COPCO GX11FF (S/N NOT GIVEN)

Compressor

{not provided} (--- GAL)

Sample Rating Trend



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0872522		
Sample Date		Client Info		25 Mar 2024		
Machine Age	hrs	Client Info		20600		
Oil Age	hrs	Client Info		812		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	0		
Lead	ppm	ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65	<1		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		26		
Zinc	ppm	ASTM D5185m		54		
Sulfur	ppm	ASTM D5185m		90		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	0		
Sodium	ppm	ASTM D5185m		2		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.12		



OIL ANALYSIS REPORT









Certificate 12367

Laboratory Sample No.

: WC0872522 Lab Number : 06138639 Unique Number : 10963447

Test Package : IND 2

(40°C)

Viscosity @ 40°C

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 04 Apr 2024 **Tested**

: 05 Apr 2024 Diagnosed : 06 Apr 2024 - Don Baldridge

₹ 0.05 Acid

ELEVATED INDUSTRIAL SOLUTIONS

120 LAWTON AVE. MONROE, OH US 45050 Contact: ROBIN PRICHARD

r.prichard@compressedairtechnologies.com T: (513)539-5155

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Acid Number

Contact/Location: ROBIN PRICHARD - COMMONOH