

OIL ANALYSIS REPORT

Area **[1241] KAESER SK 20 1066 - PACKING CORP**

Component Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




SAMPLE INFORM	/IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0872544		
Sample Date		Client Info		20 Mar 2024		
Machine Age	hrs	Client Info		35922		
Oil Age	hrs	Client Info		2358		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	0		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	90	15		
Calcium	ppm	ASTM D5185m	2	0		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		4		
Sulfur	ppm	ASTM D5185m		19337		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		5		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.42		



OIL ANALYSIS REPORT

VISUAI



	VISUAL		method	limit/base	current	history1	history2
****	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	LIGHT		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Mar20/24	Appearance	scalar	*Visual	NORML	NORML		
Mará	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.05	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPER	TIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	46	45.0	Thotory	inotory 2
			A51W D445	40	45.0		
	SAMPLE IMAGE	S	method				history2
Mar20.24	Color				•	no image	no image
	Bottom				\bigcirc	no image	no image
	Non-ferrous Meta	IIS		Mar2024 Mar2024	Acid Number		
	Abnormal Abnormal Base 40 Abnormal 45 40 45 40 45 40 45 40 45 40 45 45 40 45 45 45 45 45 45 45 45 45 45			0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0 0 0 0		. 4000cmM
Laboratory Sample No. Lab Number Unique Number Test Package discuss this sample report, Denotes test methods that thements of conformity to sp	: 10963450 : IND 2 , contact Customer Serv are outside of the ISO :	Rece Teste Diagr vice at 1-8 17025 sco	ived : 04 ed : 05 nosed : 06 800-237-1368	4 Apr 2024 5 Apr 2024 Apr 2024 - Dor 9.	n Baldridge	Contact: ROE @compressedair	LAWTON AVE MONROE, OF US 45050 BIN PRICHARE

Report Id: COMMONOH [WUSCAR] 06138642 (Generated: 04/06/2024 12:23:13) Rev: 1

Contact/Location: ROBIN PRICHARD - COMMONOH