




OIL ANALYSIS REPORT



Machine Id
Coopersville CAT 5 CPVM05BE
 Component
Biogas Engine
 Fluid
CHEVRON HDAX 9500 GAS ENGINE OIL 40 (105 GAL)

Sample Rating Trend



DIAGNOSIS

Recommendation
 No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Wear
 The tin level is abnormal. All other component wear rates are normal.

Contamination
 There is no indication of any contamination in the oil.

Fluid Condition
 The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0871590	WC0871534	WC0871529
Sample Date	Client Info		29 Mar 2024	26 Feb 2024	20 Feb 2024
Machine Age	hrs	Client Info	16119	15380	15240
Oil Age	hrs	Client Info	362	837	697
Oil Changed	Client Info		Changed	Not Changd	Not Changd
Sample Status			ABNORMAL	SEVERE	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>.11	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	<1	3	1
Chromium	ppm	ASTM D5185m	>4	0	<1	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>6	2	3	3
Lead	ppm	ASTM D5185m	>9	3	5	6
Copper	ppm	ASTM D5185m	>6	1	2	1
Tin	ppm	ASTM D5185m	>4	▲ 4	8	7
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		2	1	2
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		4	2	2
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		6	8	10
Calcium	ppm	ASTM D5185m		1770	1864	1909
Phosphorus	ppm	ASTM D5185m		248	274	280
Zinc	ppm	ASTM D5185m		318	362	358
Sulfur	ppm	ASTM D5185m		2122	1910	1822

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	127	▲ 210	179
Sodium	ppm	ASTM D5185m	>21	1	0	<1
Potassium	ppm	ASTM D5185m	>20	0	2	1

INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0	0.1	0.1
Nitration	Abs/cm	*ASTM D7624		6.7	7.7	7.5
Sulfation	Abs/.1mm	*ASTM D7415		17.9	20.3	19.7


FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414		12.7	17.6	16.2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	1.13	2.09	1.56
Base Number (BN)	mg KOH/g	ASTM D2896	5.4	3.98	4.04	3.99




OIL ANALYSIS REPORT


Non-ferrous Metals




FT-IR (Direct Trend)




Acid Number



Base Number











Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.11	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	13.7	14.1

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0871590

Lab Number : 06138720

Unique Number : 10963528

Test Package : MOB 2

Received : 04 Apr 2024

Tested : 05 Apr 2024

Diagnosed : 06 Apr 2024 - Don Baldrige

EDL NA Recips-Coopersville

Coopersville Powerstation, 15362 68th Avenue

Coopersville, MI

US 49404

Contact: Daniel Young

daniel.young@edlenergy.com

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)