

OIL ANALYSIS REPORT

Sample Rating Trend







SAVM03BE (S/N GZJ00168)

Biogas Engine

CHEVRON HDAX 9500 GAS ENGINE OIL 40 (141 GAL)

DIAGNOSIS

▲ Recommendation

We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

Elemental level of silicon (Si) above normal.


Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

S ENGINE OIL 40 (141 GAL)						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0788906	WC0788903	WC0788900
Sample Date		Client Info		02 Apr 2024	14 Mar 2024	20 Feb 2024
Machine Age	hrs	Client Info		175604	175185	174649
Oil Age	hrs	Client Info		630	211	595
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				SEVERE	NORMAL	SEVERE
CONTAMINATION	N	method	limit/base	current	history1	history2
-uel		WC Method	>4.0	<1.0	<1.0	<1.0
Nater		WC Method		NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>14	4	<1	4
Chromium	ppm	ASTM D5185m	>3	0	0	<1
Nickel	ppm	ASTM D5185m		0	0	<1
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>5	2	1	<1
_ead	ppm	ASTM D5185m	>8	0	2	1
Copper	ppm	ASTM D5185m	>5	1	<1	2
Γin	ppm	ASTM D5185m	>3	1	<1	3
/anadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		8	8	3
Barium	ppm	ASTM D5185m		0	0	5
Molybdenum	ppm	ASTM D5185m		10	9	7
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		25	22	11
Calcium	ppm	ASTM D5185m		1859	1786	1474
Phosphorus	ppm	ASTM D5185m		257	271	210
Zinc	ppm	ASTM D5185m		350	320	300
	PPIII	710 1111 20 100111		330	320	
	ppm	ASTM D5185m		1992	1895	1624
	ppm		limit/base			1624 history2
Sulfur CONTAMINANTS	ppm	ASTM D5185m	limit/base >180	1992	1895	
Sulfur CONTAMINANTS Silicon	ppm	ASTM D5185m method		1992 current	1895 history1	history2
Sulfur CONTAMINANTS Silicon Sodium	ppm	ASTM D5185m method ASTM D5185m	>180	1992 current 220	1895 history1 103	history2
Sulfur CONTAMINANTS Silicon Sodium	ppm ppm ppm	ASTM D5185m method ASTM D5185m ASTM D5185m	>180 >20	1992 current 220 1	1895 history1 103	history2 209
Gulfur CONTAMINANTS Silicon Sodium Potassium INFRA-RED	ppm ppm ppm	ASTM D5185m method ASTM D5185m ASTM D5185m ASTM D5185m	>180 >20 >20	1992 current 220 1 0	1895 history1 103 1	history2 209 0 2
Gulfur CONTAMINANTS Silicon Sodium Potassium INFRA-RED Soot %	ppm ppm ppm ppm	ASTM D5185m method ASTM D5185m ASTM D5185m ASTM D5185m method	>180 >20 >20	1992	1895 history1 103 1 0 history1	history2 209 0 2 history2
Sulfur CONTAMINANTS Silicon Sodium Potassium INFRA-RED Soot % Nitration	ppm ppm ppm ppm	ASTM D5185m method ASTM D5185m ASTM D5185m ASTM D5185m Method *ASTM D7844	>180 >20 >20	1992 current 220 1 0 current 0	1895 history1 103 1 0 history1 0	history2 209 0 2 history2 0
CONTAMINANTS Silicon Sodium Potassium INFRA-RED Soot % Nitration	ppm ppm ppm ppm Abs/.1mm	ASTM D5185m method ASTM D5185m ASTM D5185m ASTM D5185m Method *ASTM D7844 *ASTM D7624	>180 >20 >20	1992	1895 history1 103 1 0 history1 0 5.8	history2 209 0 2 history2 0 6.2
CONTAMINANTS Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation FLUID DEGRADA	ppm ppm ppm ppm Abs/.1mm	ASTM D5185m method ASTM D5185m ASTM D5185m ASTM D5185m method *ASTM D7844 *ASTM D7624 *ASTM D7415	>180 >20 >20 >20 limit/base	1992	1895 history1 103 1 0 history1 0 5.8 16.1	history2 ▲ 209 0 2 history2 0 6.2 17.9
Sulfur CONTAMINANTS Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm Abs/.1mm	ASTM D5185m method ASTM D5185m ASTM D5185m ASTM D5185m method *ASTM D7844 *ASTM D7624 *ASTM D7415 method	>180 >20 >20 >20 limit/base	1992 current 220 1 0 current 0 6.7 18.2 current	1895 history1 103 1 0 history1 0 5.8 16.1 history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Sample No. Lab Number Unique Number : 10963540

: WC0788906 : 06138732 Test Package : MOB 2

Received : 04 Apr 2024

Tested : 05 Apr 2024 Diagnosed : 06 Apr 2024 - Don Baldridge

SAND VALLEY POWER STATION, 3345 COUNTY ROAD 209 COLLINSVILLE, AL US 35961

Contact: BRANDON PEYTON brandon.peyton@energydi.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) T:

F: