


FUEL REPORT

Carilion Roanoke Memorial Hospital [4612] [Carilion Roanoke Memorial Hospital] DAY TANK 5

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUF





DIAGNOSIS

Recommendation

No corrective action is recommended at this time. All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

R) (100 GAL)				Mar2024		
SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC06139078		
Sample Date		Client Info		02 Mar 2024		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yllow	Red		
ASTM Color	scalar	*ASTM D1500		L4.0		
Visc @ 40°C	cSt	ASTM D445	3.0	2.53		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	64.2		
SULFUR CONTE	VT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	22		
Sulfur (UVF)	ppm	ASTM D5453		23		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	175		
5% Distillation Point	°C	ASTM D86		197		
10% Distill Point	°C	ASTM D86	201	206		
15% Distillation Point	°C	ASTM D86		214		
20% Distill Point	°C	ASTM D86	216	221		
30% Distill Point	°C	ASTM D86	230	235		
40% Distill Point	°C	ASTM D86	243	248		
50% Distill Point	°C	ASTM D86	255	260		
60% Distill Point	°C	ASTM D86	267	274		
70% Distill Point	°C	ASTM D86	280	287		
80% Distill Point	°C	ASTM D86	295	303		
85% Distillation Point	°C	ASTM D86		313		
90% Distill Point	°C	ASTM D86	310	324		
95% Distillation Point	°C	ASTM D86		342		
Final Boiling Point	°C	ASTM D86	341	356		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	37		
Cetane Index		ASTM D4737	<40.0	49		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.003		
ppm Water	ppm	ASTM D6304	<500	29		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



FUEL REPORT







Certificate 12367

Sample No.

: WC06139078 Lab Number : 06139078 Unique Number : 10963886

Test Package : DF-2 (Additional Tests: Fuel, Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Received : 04 Apr 2024 **Tested** : 15 Apr 2024 Diagnosed

: 15 Apr 2024 - Doug Bogart

Contact: AJAY EL Ajay@prsfuel.com T: (843)225-1777

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 210 POWELL DR

US 29483

SUMMERVILLE, SC