



# FUEL REPORT

Sample Rating Trend



**NORMAL**



Area

**Carilion Roanoke Memorial Hospital [4608]**

Machine Id

**[Carilion Roanoke Memorial Hospital] DAY TANK 1**

Component

**Diesel Fuel**

Fluid

**No.2 DIESEL FUEL (ULTRALOW SULPHUR) (100 GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC06139085</b>	---	---
Sample Date	Client Info			<b>04 Apr 2024</b>	---	---
Machine Age	hrs	Client Info		<b>0</b>	---	---
Sample Status				<b>NORMAL</b>	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yellow	<b>Red</b>	---	---
ASTM Color	scalar	*ASTM D1500		<b>L4.0</b>	---	---
Visc @ 40°C	cSt	ASTM D445	3.0	<b>2.46</b>	---	---
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	<b>62.3</b>	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	<b>32</b>	---	---
Sulfur (UVF)	ppm	ASTM D5453		<b>10</b>	---	---






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	<b>173</b>	---	---
5% Distillation Point	°C	ASTM D86		<b>196</b>	---	---
10% Distill Point	°C	ASTM D86	201	<b>205</b>	---	---
15% Distillation Point	°C	ASTM D86		<b>213</b>	---	---
20% Distill Point	°C	ASTM D86	216	<b>221</b>	---	---
30% Distill Point	°C	ASTM D86	230	<b>235</b>	---	---
40% Distill Point	°C	ASTM D86	243	<b>247</b>	---	---
50% Distill Point	°C	ASTM D86	255	<b>260</b>	---	---
60% Distill Point	°C	ASTM D86	267	<b>274</b>	---	---
70% Distill Point	°C	ASTM D86	280	<b>287</b>	---	---
80% Distill Point	°C	ASTM D86	295	<b>303</b>	---	---
85% Distillation Point	°C	ASTM D86		<b>313</b>	---	---
90% Distill Point	°C	ASTM D86	310	<b>324</b>	---	---
95% Distillation Point	°C	ASTM D86		<b>342</b>	---	---
Final Boiling Point	°C	ASTM D86	341	<b>356</b>	---	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	<b>37</b>	---	---
Cetane Index		ASTM D4737	<40.0	<b>49</b>	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>0</b>	---	---
Sodium	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	---	---
Potassium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Water	%	ASTM D6304	<0.05	<b>0.002</b>	---	---
ppm Water	ppm	ASTM D6304	<500	<b>25</b>	---	---
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	---	---
% Biodiesel	%	*In-House	<20.0	<b>0.0</b>	---	---



# FUEL REPORT






FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	<b>52</b>	---	---
Particles >6µm	ASTM D7647	>640	<b>19</b>	---	---
Particles >14µm	ASTM D7647	>80	<b>3</b>	---	---
Particles >21µm	ASTM D7647	>20	<b>1</b>	---	---
Particles >38µm	ASTM D7647	>4	<b>0</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	<b>13/11/9</b>	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Nickel	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Lead	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Iron	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Calcium	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Magnesium	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Phosphorus	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Zinc	ppm	ASTM D5185m <0.1	<b>0</b>	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC06139085

Lab Number : 06139085

Unique Number : 10963893

Test Package : DF-2 ( Additional Tests: Fuel, Screen )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 04 Apr 2024

Tested : 15 Apr 2024

Diagnosed : 15 Apr 2024 - Doug Bogart

PETROLEUM RECOVERY SERVICES

210 POWELL DR

SUMMERVILLE, SC

US 29483

Contact: AJAY EL

Ajay@prsfuel.com

T: (843)225-1777

F: