


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 3807034 (S/N 1637)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Jun 2021 Mar 2024 Mar 2024						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA015080	KCPA016359	KCP28998
Sample Date		Client Info		25 Mar 2024	25 Mar 2024	26 Jan 2021
Machine Age	hrs	Client Info		39851	39851	28661
Oil Age	hrs	Client Info		2840	2840	0
Oil Changed		Client Info		Not Changd	Not Changd	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	3	2	<1
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	2	<1
Lead	ppm	ASTM D5185m	>10	<1	<1	0
Copper	ppm	ASTM D5185m	>50	11	3	4
Tin	ppm	ASTM D5185m	>10	<1	1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	1
Barium	ppm	ASTM D5185m	90	14	2	0
Molybdenum	ppm	ASTM D5185m	0	0	1	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	100	26	55	<1
Calcium	ppm	ASTM D5185m	0	0	4	0
Phosphorus	ppm	ASTM D5185m	0	0	10	456
Zinc	ppm	ASTM D5185m	0	<1	29	3
Sulfur	ppm	ASTM D5185m	23500	19509	22448	1871
CONTAMINANTS	1	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	2	3
Sodium	ppm	ASTM D5185m		18	25	<1
Potassium	ppm	ASTM D5185m	>20	6	5	0
Water	%	ASTM D6304	>0.05	0.010	0.026	<b>△</b> 0.126
ppm Water	ppm	ASTM D6304	>500	108	262	<u>1260</u>
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		172732	2353	
Particles >6µm		ASTM D7647	>1300	<u> </u>	449	
Particles >14µm		ASTM D7647	>80	<b>4179</b>	42	
Particles >21µm		ASTM D7647	>20	<b>A</b> 329	16	
Particles >38µm		ASTM D7647	>4	3	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>25/24/19</b>	18/16/13	
Oli Oloariiiriooo		(0)	, , , , , , ,	25/24/15		

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.34 0.151 Contact/Location: M. PIERCE - ZATNOR



# OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: 06139274

: KCPA015080 Lab Number Unique Number : 10964082

Received : 04 Apr 2024 **Tested** Diagnosed

: 05 Apr 2024 Test Package : IND 2 ( Additional Tests: KF, PrtCount )

: 06 Apr 2024 - Don Baldridge

620 SPRING ST NORTH DIGHTON, MA US 02764 Contact: M. PIERCE mpierce@zatecinc.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: