


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id 211 Component Compressor

{not provided} (--- GAL)

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

### Wear

The iron level is abnormal. All other component wear rates are normal.

### Contamination

There is no indication of any contamination in the

### **Fluid Condition**

The AN level is acceptable for this fluid.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0858347	WC0774375	WC0858336
Sample Date		Client Info		01 Apr 2024	15 Mar 2024	13 Feb 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	SEVERE
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>168</b>	<b>▲</b> 180	<b>▲</b> 772
Chromium	ppm	ASTM D5185m	>5	0	0	0
Nickel	ppm	ASTM D5185m		<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>15	1	<1	1
Lead	ppm	ASTM D5185m	>65	<1	0	0
Copper	ppm	ASTM D5185m	>65	0	0	<1
Tin	ppm	ASTM D5185m	>10	3	2	8
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	3	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		32	<1	4
Phosphorus	ppm	ASTM D5185m		16	9	0
Zinc	ppm	ASTM D5185m		2	0	6
Sulfur	ppm	ASTM D5185m		1475	1480	5428
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	30	<b>▲</b> 38	25
Sodium	ppm	ASTM D5185m		529	532	2521
Potassium	ppm	ASTM D5185m	>20	456	433	2117
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.06	0.56	0.32



# **OIL ANALYSIS REPORT**





Certificate 12367

Laboratory Sample No.

: WC0858347

Lab Number : 06139344 Unique Number : 10964152

Received : 04 Apr 2024 **Tested** 

: 10 Apr 2024 Diagnosed

: 10 Apr 2024 - Jonathan Hester

Test Package: MOB 2 (Additional Tests: FT-IR, KV100, TBN)

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ggarza@esisolutions.com

Contact/Location: GABE GARAZA - TERAPP

1313 HOLLAND ROAD SUITE A

Contact: GABE GARAZA

Report Id: TERAPP [WUSCAR] 06139344 (Generated: 04/10/2024 15:07:42) Rev: 1

Page 2 of 2

APPLETON, WI

US 54911

T:

F: