




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

LGS00181

Component

Middle Biogas Engine

Fluid

CITGO PACEMAKER GAS ENGINE LFG LA 40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2	
Sample Number	Client Info	WC0803405	WC0803408	WC0803409	
Sample Date	Client Info	01 Apr 2024	25 Mar 2024	19 Mar 2024	
Machine Age	hrs	Client Info	66547	66383	66246
Oil Age	hrs	Client Info	327	163	26
Oil Changed	Client Info	N/A	N/A	N/A	
Sample Status		NORMAL	NORMAL	NORMAL	

CONTAMINATION

method	limit/base	current	history1	history2
Fuel	WC Method >4.0	<1.0	<1.0	<1.0
Water	WC Method >0.1	NEG	NEG	NEG
Glycol	WC Method	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >45	6	8	2
Chromium	ppm ASTM D5185m >2	0	<1	0
Nickel	ppm ASTM D5185m >2	<1	1	0
Titanium	ppm ASTM D5185m	0	<1	0
Silver	ppm ASTM D5185m >5	0	0	0
Aluminum	ppm ASTM D5185m >10	2	2	<1
Lead	ppm ASTM D5185m >5	1	1	0
Copper	ppm ASTM D5185m >14	1	3	<1
Tin	ppm ASTM D5185m >13	4	4	1
Vanadium	ppm ASTM D5185m	0	<1	0
Cadmium	ppm ASTM D5185m	0	<1	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	<1	3	1
Barium	ppm ASTM D5185m	0	0	0
Molybdenum	ppm ASTM D5185m	<1	8	2
Manganese	ppm ASTM D5185m	<1	<1	<1
Magnesium	ppm ASTM D5185m	10	26	24
Calcium	ppm ASTM D5185m	1403	1464	1411
Phosphorus	ppm ASTM D5185m	287	322	302
Zinc	ppm ASTM D5185m	346	368	351
Sulfur	ppm ASTM D5185m	3471	3150	2789

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >200	197	136	49
Sodium	ppm ASTM D5185m	7	<1	<1
Potassium	ppm ASTM D5185m >20	7	2	0

INFRA-RED

method	limit/base	current	history1	history2
Soot %	% *ASTM D7844	0	0	0
Nitration	Abs/cm *ASTM D7624 >20	3.4	3.3	3.0
Sulfation	Abs/.1mm *ASTM D7415 >30	17.0	15.9	15.0


FLUID DEGRADATION

method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414 >25	7.4	7.1	6.8
Acid Number (AN)	mg KOH/g ASTM D8045 1.16	0.85	1.16	1.159
Base Number (BN)	mg KOH/g ASTM D2896 5	2.90	3.50	4.18




OIL ANALYSIS REPORT


FT-IR (Direct Trend)




Acid Number



Base Number



Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	12.5	12.6

GRAPHS


Iron (ppm)




Lead (ppm)




Aluminum (ppm)




Chromium (ppm)




Copper (ppm)




Silicon (ppm)



Viscosity @ 100°C



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0803405
 Lab Number : 06139346
 Unique Number : 10964154
 Test Package : MOB 2

Received : 04 Apr 2024
 Tested : 05 Apr 2024
 Diagnosed : 06 Apr 2024 - Don Baldrige

BLACK OAK
 5054 HWY HH
 HARTVILLE, MO
 US 65667

Contact: CHIP MATHEWS
 chip.matthews@cubedistrictenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
 F: