

FUEL REPORT

Sample Rating Trend



Machine Id

STEWARD HEALTH CARE - MRMC DAY TANK 1

Tank Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. There is no indication of any contamination in the fuel.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

) (275 GAL)		Mar2024				
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number	,,, (11011	Client Info	mmusacc	WCDF4581		motory
Sample Date		Client Info		28 Mar 2024		
Machine Age	mls	Client Info		0		
Sample Status	11115	Ciletit IIIIO		NORMAL		
· ·						
PHYSICAL PROP	'ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yllow	Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
/isc @ 40°C	cSt	ASTM D445	3.0	2.73		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	70.4		
Cloud Point	°C	ASTM D5771		-12		
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	938		
Sulfur (UVF)	ppm	ASTM D5453		795		
DISTILLATION		method	limit/base	current	history1	history2
nitial Boiling Point	°C	ASTM D86	165	183		
5% Distillation Point	°C	ASTM D86		205		
10% Distill Point	°C	ASTM D86	201	213		
15% Distillation Point	°C	ASTM D86		221		
20% Distill Point	°C	ASTM D86	216	228		
30% Distill Point	°C	ASTM D86	230	242		
10% Distill Point	°C	ASTM D86	243	255		
50% Distill Point	°C	ASTM D86	255	267		
60% Distill Point	°C	ASTM D86	267	281		
70% Distill Point	°C	ASTM D86	280	294		
30% Distill Point	°C	ASTM D86	295	309		
35% Distillation Point	°C	ASTM D86		319		
90% Distill Point	°C	ASTM D86	310	330		
95% Distillation Point	°C	ASTM D86		345		
Final Boiling Point	°C	ASTM D86	341	359		
IGNITION QUALIT	ГΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36		
Cetane Index		ASTM D4737	<40.0	48		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.003		
opm Water	ppm	ASTM D6304	<500	34		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	< 20.0	0.0		



FUEL REPORT







Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WCDF4581 Lab Number : 06139425 Unique Number : 10964233

Received **Tested** Diagnosed

: 04 Apr 2024 : 15 Apr 2024

: 15 Apr 2024 - Doug Bogart

Test Package : DF-2 (Additional Tests: CldPt, Fuel, Screen) To discuss this sample report, contact Customer Service at 1-800-237-1369.

US 32907 Contact: WENDALL STRODERD wendall@tankwizards.com

T: (321)427-5149 F: (321)574-4131

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: 321-285-8878 X1 - WENDALL STRODERD - TANPAL

TANK WIZARDS

PALM BAY, FL

1511 MASTERS RD NW