


OIL ANALYSIS REPORT

NORMAL

SMART OIL 6000 **HERTZ VD020137**

Component Compressor



Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UHK06140032		
Sample Date		Client Info		01 Apr 2024		
Machine Age	hrs	Client Info		982		
Oil Age	hrs	Client Info		982		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	3		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m	20	0		
Phosphorus	ppm	ASTM D5185m		41		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		454		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.14		



OIL ANALYSIS REPORT



VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	ΓIES	method	limit/base	current	history1	history2


Abnormal						
, , i a	 	 	 	 		
2						
50+						
10						
48 - Base	 	 	 	 		
T						
14						
14						
14 - Abnormal						
Abnormal						
14 12 Abnormal						
42 - Abnormal					••••	

SAMPLE IMAGES Color no image no image **Bottom** no image no image

46.6

GRAPHS


Visc @ 40°C




cSt

ASTM D445 46

Non-terro	
CODD	
8 - management lead	
E 6+	
E 4	
2	
0	
724	vpr1/24
Apr1/24	Apr1









Certificate 12367

Laboratory

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : UHK06140032 Lab Number : 06140032

Test Package : IND 2

Unique Number : 10964840

Received : 05 Apr 2024 Tested : 08 Apr 2024 Diagnosed

: 08 Apr 2024 - Don Baldridge

ATLANTA AIR COMPRESSOR - HERTZ 123 MERCHANTS PARK DR HOSCHTON, GA

> US 30548 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCATLHER [WUSCAR] 06140032 (Generated: 04/08/2024 14:42:44) Rev: 1

Contact/Location: Service Manager - UCATLHER

T:

F: