




OIL ANALYSIS REPORT



Machine Id
Brent Run CAT 3 BRRM03BE
 Component
Biogas Engine
 Fluid
CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)

Sample Rating Trend



DIRT



DIAGNOSIS

Recommendation
 Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. We recommend an early resample to monitor this condition. (Customer Sample Comment: End of life oil sample after working on all 3 crankcase filters, changed oil and filters)

Wear
 The tin level is abnormal. All other component wear rates are normal.

Contamination
 Elemental level of silicon (Si) above normal.

Fluid Condition
 The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0776765	WC0776763	WC0776706
Sample Date	Client Info		02 Apr 2024	26 Mar 2024	11 Mar 2024
Machine Age	hrs	Client Info	50852	50688	50346
Oil Age	hrs	Client Info	740	576	234
Oil Changed	Client Info		Changed	Not Changd	Not Changd
Sample Status			SEVERE	SEVERE	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method		NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>14	4	3	3
Chromium	ppm	ASTM D5185m	>3	0	0	<1
Nickel	ppm	ASTM D5185m		0	<1	<1
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>5	3	2	2
Lead	ppm	ASTM D5185m	>8	0	0	<1
Copper	ppm	ASTM D5185m	>5	2	2	2
Tin	ppm	ASTM D5185m	>3	4	3	3
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		3	2	3
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		1	<1	1
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m		9	7	9
Calcium	ppm	ASTM D5185m		1937	1858	1712
Phosphorus	ppm	ASTM D5185m		294	263	268
Zinc	ppm	ASTM D5185m		358	322	330
Sulfur	ppm	ASTM D5185m		3428	2990	2683

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>180	248	217	173
Sodium	ppm	ASTM D5185m	>20	1	2	0
Potassium	ppm	ASTM D5185m	>20	<1	0	2

INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624		6.6	6.5	5.9
Sulfation	Abs/.1mm	*ASTM D7415		24.0	23.4	20.4


FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414		17.1	16.4	12.7
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	1.60	1.62	1.25
Base Number (BN)	mg KOH/g	ASTM D2896	5.4	3.06	3.51	3.46




OIL ANALYSIS REPORT


▲ Non-ferrous Metals




● FT-IR (Direct Trend)




Acid Number



Acid Number











Base Number



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	13.8	13.6

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0776765
 Lab Number : 06140092
 Unique Number : 10964900
 Test Package : MOB 2

Received : 05 Apr 2024
 Tested : 08 Apr 2024
 Diagnosed : 08 Apr 2024 - Don Baldrige

EDL NA Recips-Brent Run
 Brent Run Power Station, 8383 Vienna Road
 Montrose, MI
 US 48457-9141
 Contact: Rob Stewart
 Rob.Stewart@energydevelopments.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: