




# COOLANT REPORT

Sample Rating Trend



**NORMAL**



Area

**Detroit**

Machine Id

**[Detroit] Coolant - Port Genset**

Component

**Coolant**

Fluid

**CATERPILLAR ELC (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service. ( Customer Sample Comment: Chris Wray )

### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

### Contaminants

There is no indication of any contamination in the coolant.

### Coolant Condition

Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0804775</b>	WC0731928	WC0731972
Sample Date	Client Info		<b>25 Mar 2024</b>	30 Jan 2023	07 Nov 2022
Machine Age	hrs	Client Info	<b>22305</b>	0	16082
Oil Age	hrs	Client Info	<b>0</b>	0	16082
Oil Changed	Client Info		<b>N/A</b>	N/A	Not Changd
Sample Status			<b>NORMAL</b>	SEVERE	NORMAL

## PHYSICAL TEST RESULTS

	method	limit/base	current	history1	history2
Glycol Type	FT-IR		<b>---</b>	---	---
Specific Gravity	*ASTM D1298		<b>1.044</b>	1.031	1.043
pH	Scale 0-14	ASTM D1287	<b>8.56</b>	8.54	8.62
Nitrites	ppm	AP-053:2009	<b>524</b>	448	372
Reserve Alkalinity	Scale 0-20	*ASTM D1121	<b>---</b>	---	---
Percentage Glycol	%	ASTM D3321	<b>32.6</b>	23.4	32.3
Freezing Point	°F	ASTM D3321	<b>1</b>	12	1
Total Dissolved Solids			<b>237.0</b>	167.0	237.0
Carboxylate			<b>fail</b>	fail	fail

## CORROSION INHIBITORS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D6130	0	<b>3</b>	37	10
Phosphorus	ppm	ASTM D6130	0	<b>2</b>	30	0
Boron	ppm	ASTM D6130	0	<b>7</b>	28	25
Molybdenum	ppm	ASTM D6130	950	<b>451</b>	70	829

## CORROSION

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D6130	>15	<b>2</b>	▲ 33	4
Aluminum	ppm	ASTM D6130	>10	<b>&lt;1</b>	2	0
Copper	ppm	ASTM D6130	>10	<b>1</b>	2	<1
Lead	ppm	ASTM D6130	>10	<b>&lt;1</b>	2	0
Tin	ppm	ASTM D6130	>10	<b>&lt;1</b>	<1	0
Zinc	ppm	ASTM D6130		<b>0</b>	1	0

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Chlorine	ppm	ASTM D6130		<b>24</b>	124	34

## CARRIER SALTS


	method	limit/base	current	history1	history2	
Sodium	ppm	ASTM D6130		<b>3327</b>	4056	4786
Potassium	ppm	ASTM D6130		<b>6</b>	186	12







## SCALE POTENTIAL

	method	limit/base	current	history1	history2	
Calcium	ppm	ASTM D6130		<b>23</b>	85	43
Magnesium	ppm	ASTM D6130		<b>4</b>	3	5









# COOLANT REPORT



VISUAL	method	limit/base	current	history1	history2
Coolant Color	*Visual		Orange	Red	Red
Coolant Appearance	*Visual	Clear	normal	normal	normal
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0804775 **Received** : 05 Apr 2024  
**Lab Number** : 06140422 **Tested** : 10 Apr 2024  
**Unique Number** : 10965230 **Diagnosed** : 10 Apr 2024 - Jonathan Hester  
**Test Package** : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType, ICP, KF )

**MARATHON PETROLEUM CO.**  
 101 12TH ST  
 CATLETTSBURG, KY  
 US 41169  
 Contact: CORY GUMBERT  
 cagumbert@marathonpetroleum.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (606)585-3950

F: x: