


COOLANT REPORT



OKLAHOMA/102/EG - SKID STEER 53.148L [OKLAHOMA^102^EG - SKID STEER] Component Coolant

EXTENDED LIFE COOLANT (--- GAL)





DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition


Carboxylate test failed. The pH level of this fluid is within the acceptable limits. Glycol and nitrite levels are acceptable.


LANI (GAL) Judozo Septoza Mardoza						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0914578	WC0834048	WC0453804
Sample Date		Client Info		22 Mar 2024	27 Sep 2023	10 Jul 2020
Machine Age	hrs	Client Info		3770	2992	250
Oil Age	hrs	Client Info		3770	2992	0
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.068	1.067	
ρΗ	Scale 0-14	ASTM D1287		7.43	7.28	8.20
Nitrites	ppm	AP-053:2009		824	184	600
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		50.8	49.8	50
Freezing Point	°F	ASTM D3321		-35	-33	-37
Total Dissolved Solids				367.5	366.5	362.0
Carboxylate				fail	fail	pass
CORROSION INHI	BITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130		6	15	6
Phosphorus	ppm	ASTM D6130		0	<1	41
Boron	ppm	ASTM D6130		0	13	0
Molybdenum	ppm	ASTM D6130		583	406	433
CORROSION		method	limit/base	current	history1	history2
ron	ppm	ASTM D6130	>15	0	1	0
Aluminum	ppm	ASTM D6130	>10	2	9	2
Copper	ppm	ASTM D6130	>10	<1	1	0
_ead	ppm	ASTM D6130	>10	<1	1	0
Γin	ppm	ASTM D6130	>10	<1	1	<1
Zinc	ppm	ASTM D6130		3	43	0
CONTAMINANTS						
CONTAMINANTS		method	limit/base	current	history1	history2
	ppm	method ASTM D6130	limit/base	current 7	history1	history2
Chlorine CARRIER SALTS			limit/base			
Chlorine		ASTM D6130		7	16	6
Chlorine CARRIER SALTS	ppm	ASTM D6130 method		7 current	16 history1	6 history2
Chlorine CARRIER SALTS Sodium	ppm ppm ppm	ASTM D6130 method ASTM D6130		7 current 3557	16 history1 2830	6 history2 3129
Chlorine CARRIER SALTS Sodium Potassium	ppm ppm ppm	ASTM D6130 method ASTM D6130 ASTM D6130	limit/base	7 current 3557 698	16 history1 2830 698	6 history2 3129 522



COOLANT REPORT











Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06140449

: WC0914578 Unique Number : 10965257

Received **Tested** Diagnosed

: 05 Apr 2024 : 10 Apr 2024

: 10 Apr 2024 - Jonathan Hester Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType, ICP)

SHERWOOD CONSTRUCTION CO INC 3219 WEST MAY ST WICHITA, KS US 67213 Contact: JASON ANDERSON

jason.anderson@sherwood.net

T: (918)609-8800

Certificate 12367

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)