

# **OIL ANALYSIS REPORT**

Sample Rating Trend

ISO

Machine Id

## KAESER BSD 50 5590988 (S/N 1523) Component Compressor

Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016983	KCP53175	KCP38379
Sample Date		Client Info		02 Apr 2024	01 Feb 2023	07 Mar 2022
Machine Age	hrs	Client Info		52882	42693	34948
Oil Age	hrs	Client Info		4869	6000	8080
Oil Changed		Client Info		Not Changd	Changed	Changed
Sample Status				ATTENTION	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	6	6	11
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	0	0	0	0
Magnesium	ppm	ASTM D5185m	100	2	0	0
Calcium	ppm		0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	3	10
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	23500	20083	16693	12049
CONTAMINANTS	ppm	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m	00	1	0	<1
Potassium	ppm	ASTM D5185m		1	<1	0
Water	%	ASTM D6304		0.004	0.003	0.003
ppm Water	ppm	ASTM D6304		43	31.6	25.8
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3143	3545	9981
Particles >6µm		ASTM D7647		896	797	<u> </u>
Particles >14µm		ASTM D7647	>80	<b>108</b>	27	▲ 176
Particles >21µm		ASTM D7647		<u> </u>	5	<u> </u>
Particles >38µm		ASTM D7647	>4	1	0	1
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>e</b> 19/17/14	19/17/12	▲ 19/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.41	0.35	0.38


Report Id: BUZJEF [WUSCAR] 06140639 (Generated: 04/09/2024 12:14:16) Rev: 1


0.41 0.35 0.38 Contact/Location: JOHN VANRIJSWIJCK - BUZJEF














# **OIL ANALYSIS REPORT**

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	44.7	45.1	44.5
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color				a.		
Bottom					$\bigcirc$	

GRAPHS Particle Count Ferrous Alloys 491.52 10 122,880 30,720 7,680 20 8 Mar10/21 Feb3/20 Apr2/24 wr11/15 Mar7/22 kpr13/18 4406 Mar6/ per 1,920 19999 Non-ferrous Metals 480 15 120 30 Apr11/19 Mar10/21 Mar7/22 kpr2/24 Feb3/20 Mark 21 Viscosity @ 40°C Acid Number 60 (B/1.20 HOX 0.96 S 55 () 00 50 Abnorma Ë 0.72 45 · 은 0.48 ŝ LIN 0.24 40 Se 0.00 PC 35 Apr2/24 -Feb3/20. Apr13/18 Mar10/21 Mar7/22 Feb3/20 Mar7/22 pr2/24 Apr13/18 pr11/19 Mar10/21 Apr11/19 **Nar6/1** Mar6/7 **BUZZI UNICEM** Received : 05 Apr 2024 1350 BATES BOWYER AVE



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : KCPA016983 Lab Number : 06140639 Tested JEFFERSONVILLE, IN : 08 Apr 2024 Diagnosed Unique Number : 10965447 : 09 Apr 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount) Contact: JOHN VANRIJSWIJCK Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. john.vanrijswijck@buzziunicemusa.com \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: BUZJEF [WUSCAR] 06140639 (Generated: 04/09/2024 12:14:16) Rev: 1

Contact/Location: JOHN VANRIJSWIJCK - BUZJEF

Page 2 of 2

US 47130

Т:

F: