

# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER BSD 50T 6244558 (S/N 1426)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		L		Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016909		
Sample Date		Client Info		02 Apr 2024		
Machine Age	hrs	Client Info		24678		
Oil Age	hrs	Client Info		0		
Oil Changed	1110	Client Info		Changed		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	6		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m	/10	0		
Cadmium	ppm	ASTM D5185m		0		
	ррпп					
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	15		
Calcium	ppm		2	0		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		19912		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		6		
Potassium	ppm	ASTM D5185m	>20	2		
Water	%	ASTM D6304	>0.05	0.005		
ppm Water	ppm	ASTM D6304	>500	59		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		484		
Particles >6µm		ASTM D7647	>1300	116		
Particles >14µm		ASTM D7647	>80	8		
Particles >21µm		ASTM D7647	>20	2		
Particles >38μm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	16/14/10		
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2
Acid Number (AN)	ma 1/011/-	VCTM D004E	0.4	0.27		

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.37



## **OIL ANALYSIS REPORT**





Laboratory Sample No. Lab Number

: KCPA016909 : 06140655 Unique Number : 10965463

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested** 

: 08 Apr 2024 Diagnosed

: 09 Apr 2024 - Don Baldridge Test Package : IND 2 ( Additional Tests: KF, PrtCount )

: 05 Apr 2024

US 37086 Contact: SERVICE MANAGER

ONE INGRAM BLVD.

LAVERGNE, TN

Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: