


PROBLEM SUMMARY

Area
TANK FARM
Machine Id
TK-21 AGITATOR
Component
Gearbox
Fluid
SHELL OMALA S2 G 220 (38 LTR)


Sample Rating Trend



WATER



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Replace the oil at your earliest convenience. Water is substantially elevated. Flush the agitator before refilling and returning to service. Identify the ingress source for the water.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	---
Water	%	ASTM D6304	>0.2	▲ 0.690	▲ 0.263	---
ppm Water	ppm	ASTM D6304	>2000	▲ 6900	▲ 2630	---
Silt	scalar	*Visual	NONE	▲ HEAVY	▲ HEAVY	---
Free Water	scalar	*Visual		▲ 2.0	NEG	---

Customer Id: HEXLUL
Sample No.: PLS0000517
Lab Number: 06141135
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Mike Johnson +1 (615)771-6030
mike.johnson@amrri.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

DEGRADATION



11 May 2023 Diag: Mike Johnson


Change the oil at your earliest possible convenience. Flush the unit with ISO 32 turbine oil following the drain to remove any residual wet oil from the drive. Resample following the change to verify moisture is removed. The wear rate is low and acceptable. However, this sample (TK-21 Agitator) appears to be the first for this drive. It is not clear at this time whether this Fe PPM value is normal or not normal yet. Continue to observe. The moisture level is exceptional. Particle count cannot be conducted when the oil is this wet. The oil is severely wet and severely oxidized. This is a typical failure mode for water intrusion into gear oil. Replace as soon as possible.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
TANK FARM
Machine Id
TK-21 AGITATOR
Component
Gearbox
Fluid
SHELL OMALA S2 G 220 (38 LTR)

DIAGNOSIS

▲ Recommendation

Replace the oil at your earliest convenience. Water is substantially elevated. Flush the agitator before refilling and returning to service. Identify the ingress source for the water.

Wear

The wear rate is low and steady

▲ Contamination

Moisture load is high. Particle count cannot be conducted at this moisture level.

Fluid Condition

Fluid health is compromised by the moisture level.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PLS0000517	PLS0000513	---
Sample Date	Client Info			12 Mar 2024	11 May 2023	---
Machine Age	hrs	Client Info		0	0	---
Oil Age	hrs	Client Info		0	0	---
Oil Changed	Client Info			N/A	N/A	---
Sample Status				SEVERE	SEVERE	---

WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		23	20	---
Iron	ppm	ASTM D5185m	>200	29	28	---
Chromium	ppm	ASTM D5185m	>15	<1	<1	---
Nickel	ppm	ASTM D5185m	>15	<1	<1	---
Titanium	ppm	ASTM D5185m		<1	<1	---
Silver	ppm	ASTM D5185m		<1	0	---
Aluminum	ppm	ASTM D5185m	>25	3	4	---
Lead	ppm	ASTM D5185m	>100	<1	0	---
Copper	ppm	ASTM D5185m	>200	1	0	---
Tin	ppm	ASTM D5185m	>25	<1	1	---
Vanadium	ppm	ASTM D5185m		<1	0	---
Cadmium	ppm	ASTM D5185m		<1	0	---






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	4.4	3	1	---
Barium	ppm	ASTM D5185m	0.0	1	0	---
Molybdenum	ppm	ASTM D5185m	0	<1	0	---
Manganese	ppm	ASTM D5185m		<1	<1	---
Magnesium	ppm	ASTM D5185m	0	9	3	---
Calcium	ppm	ASTM D5185m	0	20	39	---
Phosphorus	ppm	ASTM D5185m	215	325	347	---
Zinc	ppm	ASTM D5185m	0	58	6	---
Sulfur	ppm	ASTM D5185m	7039	5293	7418	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	5	6	---
Sodium	ppm	ASTM D5185m		5	<1	---
Potassium	ppm	ASTM D5185m	>20	1	1	---
Water	%	ASTM D6304	>0.2	▲ 0.690	▲ 0.263	---
ppm Water	ppm	ASTM D6304	>2000	▲ 6900	▲ 2630	---

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.1	0.2	---
Nitration	Abs/cm	*ASTM D7624		3.6	3.6	---
Sulfation	Abs/.1mm	*ASTM D7415		79.0	▲ 105.7	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414		92.9	▲ 99.4	---
Acid Number (AN)	mg KOH/g	ASTM D8045		0.82	0.55	---


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ HEAVY	▲ HEAVY
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	HAZY	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	0.2%	0.2%
Free Water	scalar	*Visual		▲ 2.0	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	223	217

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PLS0000517 **Received** : 08 Apr 2024
Lab Number : 06141135 **Tested** : 22 Apr 2024
Unique Number : 10965943 **Diagnosed** : 30 May 2024 - Mike Johnson
Test Package : IND 2 (Additional Tests: FT-IR, KF, PQ)

HEXION INC - LULING PLANT
 12513 QUEENIE RD
 LULING, LA
 US 70070
 Contact: JEFF RENTFROW
 jeff.rentfrow@hexion.com;mike.johnson@amrri.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)