


OIL ANALYSIS REPORT

Sample Rating Trend



CONTAMINANT



Area
TANK FARM
Machine Id
COOLING TOWER FAN CT1A
Component
Gearbox
Fluid
SHELL MORLINA S4 B 220 (--- LTR)

DIAGNOSIS

Recommendation

No corrective actions. Resample in 3 months.

Wear

Wear rate is low and steady.

Contamination

Particulate is typical for new oil conditions.

Moisture is nil.

Fluid Condition

Oil health indicators suggest the oil is acceptable for continued use.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PLS0000519	PLS0000514	---
Sample Date	Client Info			12 Mar 2024	18 Apr 2023	---
Machine Age	hrs	Client Info		0	0	---
Oil Age	hrs	Client Info		0	0	---
Oil Changed	Client Info			N/A	N/A	---
Sample Status				ATTENTION	SEVERE	---

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.2	NEG	NEG	---


WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		17	9	---
Iron	ppm	ASTM D5185m	>200	27	70	---
Chromium	ppm	ASTM D5185m	>15	<1	<1	---
Nickel	ppm	ASTM D5185m	>15	<1	1	---
Titanium	ppm	ASTM D5185m		<1	0	---
Silver	ppm	ASTM D5185m		0	0	---
Aluminum	ppm	ASTM D5185m	>25	2	<1	---
Lead	ppm	ASTM D5185m	>100	<1	<1	---
Copper	ppm	ASTM D5185m	>200	1	<1	---
Tin	ppm	ASTM D5185m	>25	<1	<1	---
Vanadium	ppm	ASTM D5185m		<1	0	---
Cadmium	ppm	ASTM D5185m		<1	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	---
Barium	ppm	ASTM D5185m		0	0	---
Molybdenum	ppm	ASTM D5185m		<1	0	---
Manganese	ppm	ASTM D5185m		<1	<1	---
Magnesium	ppm	ASTM D5185m		1	2	---
Calcium	ppm	ASTM D5185m		0	2	---
Phosphorus	ppm	ASTM D5185m		229	▲ 187	---
Zinc	ppm	ASTM D5185m		184	▲ 214	---
Sulfur	ppm	ASTM D5185m		587	▲ 678	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	4	3	---
Sodium	ppm	ASTM D5185m		0	<1	---
Potassium	ppm	ASTM D5185m	>20	1	1	---

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.1	0.1	---
Nitration	Abs/cm	*ASTM D7624		2.9	2.9	---
Sulfation	Abs/.1mm	*ASTM D7415		79.0	48.6	---

OIL ANALYSIS REPORT




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	8775	2617	---
Particles >6µm	ASTM D7647	>5000	3020	659	---
Particles >14µm	ASTM D7647	>640	356	73	---
Particles >21µm	ASTM D7647	>160	123	16	---
Particles >38µm	ASTM D7647	>40	9	2	---
Particles >71µm	ASTM D7647	>10	2	0	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	20/19/16	19/17/13	---

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm	*ASTM D7414	61.8	53.5	---
Acid Number (AN)	mg KOH/g	ASTM D8045	0.76	▲ 1.01	---

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	MILKY	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	NEG	0.2%
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	213	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PLS0000519 **Received** : 08 Apr 2024
Lab Number : 06141136 **Tested** : 09 Apr 2024
Unique Number : 10965944 **Diagnosed** : 30 May 2024 - Mike Johnson
Test Package : IND 2 (Additional Tests: FT-IR, PQ, PrtCount)

HEXION INC - LULING PLANT
 12513 QUEENIE RD
 LULING, LA
 US 70070
 Contact: JEFF RENTFROW
 jeff.rentfrow@hexion.com;mike.johnson@amri.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)