




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id

## PRESS 2

Component

### Hydraulic System

Fluid

#### AW HYDRAULIC OIL ISO 32 (--- GAL)

#### DIAGNOSIS

##### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

##### Wear

All component wear rates are normal.

##### Contamination

There is a high amount of particulates present in the oil.

##### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0873116</b>	WC0819737	WC0845579
Sample Date	Client Info			<b>04 Apr 2024</b>	13 Dec 2023	09 Aug 2023
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.05	<b>NEG</b>	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<b>2</b>	11	3
Chromium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	<1	0
Nickel	ppm	ASTM D5185m	>20	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>20	<b>3</b>	3	<1
Lead	ppm	ASTM D5185m	>20	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m	>20	<b>2</b>	7	3
Tin	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	5	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	5	<b>&lt;1</b>	<1	<1
Manganese	ppm	ASTM D5185m		<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m	25	<b>3</b>	5	6
Calcium	ppm	ASTM D5185m	200	<b>38</b>	82	82
Phosphorus	ppm	ASTM D5185m	300	<b>118</b>	301	347
Zinc	ppm	ASTM D5185m	370	<b>178</b>	431	434
Sulfur	ppm	ASTM D5185m	2500	<b>788</b>	2473	2820





CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<b>1</b>	<1	1
Sodium	ppm	ASTM D5185m		<b>5</b>	0	0
Potassium	ppm	ASTM D5185m	>20	<b>2</b>	1	0

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<b>▲ 39136</b>	▲ 35746	---
Particles >6µm		ASTM D7647	>1300	<b>▲ 7125</b>	▲ 7369	---
Particles >14µm		ASTM D7647	>160	<b>▲ 274</b>	▲ 328	---
Particles >21µm		ASTM D7647	>40	<b>▲ 47</b>	40	---
Particles >38µm		ASTM D7647	>10	<b>1</b>	0	---
Particles >71µm		ASTM D7647	>3	<b>0</b>	0	---
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<b>▲ 22/20/15</b>	▲ 22/20/16	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.57	<b>0.41</b>	0.36	0.42




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	32	34.1	31.9	35.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0873116      **Received** : 08 Apr 2024  
**Lab Number** : 06141265      **Tested** : 09 Apr 2024  
**Unique Number** : 10966073      **Diagnosed** : 10 Apr 2024 - Don Baldrige  
**Test Package** : IND 2

**BLUE RIDGE FIBERBOARD**  
 250 KNIGHT CELOTEX DR  
 DANVILLE, VA  
 US 24541  
 Contact: Jerald Caldwell  
 JCaldwell@blueridgefiberboard.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)