


# OIL ANALYSIS REPORT

Sample Rating Trend



Area  
**CRYO**  
 Machine Id  
**C-162 (S/N XC-0622)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**TULCO LUBSOIL SYN RL WI 100 (250 GAL)**

## DIAGNOSIS

- Recommendation**  
 The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.
- Wear**  
 The iron level is abnormal. All other component wear rates are normal.
- Contamination**  
 There is a high amount of particulates present in the oil.
- Fluid Condition**  
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>TO20000357</b>	TO20000354	TO20000192
Sample Date	Client Info	<b>26 Mar 2024</b>	19 Oct 2023	11 Apr 2023
Machine Age	hrs	<b>11</b>	11	11
Oil Age	hrs	<b>11</b>	11	11
Oil Changed	Client Info	<b>Oil Added</b>	Changed	Oil Added
Sample Status		<b>ABNORMAL</b>	SEVERE	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >8	<b>▲ 17</b>	▲ 16	16
Chromium ppm	ASTM D5185m >2	<b>0</b>	<1	0
Nickel ppm	ASTM D5185m	<b>0</b>	<1	0
Titanium ppm	ASTM D5185m	<b>0</b>	<1	0
Silver ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum ppm	ASTM D5185m >3	<b>0</b>	1	5
Lead ppm	ASTM D5185m >2	<b>&lt;1</b>	0	0
Copper ppm	ASTM D5185m >8	<b>0</b>	2	13
Tin ppm	ASTM D5185m >4	<b>11</b>	10	8
Vanadium ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium ppm	ASTM D5185m	<b>0</b>	<1	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m	<b>0</b>	0	0
Barium ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum ppm	ASTM D5185m	<b>0</b>	<1	0
Manganese ppm	ASTM D5185m	<b>0</b>	0	<1
Magnesium ppm	ASTM D5185m	<b>0</b>	0	4
Calcium ppm	ASTM D5185m	<b>99</b>	89	84
Phosphorus ppm	ASTM D5185m 1500	<b>937</b>	940	859
Zinc ppm	ASTM D5185m	<b>36</b>	39	52
Sulfur ppm	ASTM D5185m	<b>0</b>	0	0

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >15	<b>3</b>	4	4
Sodium ppm	ASTM D5185m	<b>0</b>	<1	0
Potassium ppm	ASTM D5185m >20	<b>0</b>	2	<1
Water %	ASTM D6304 >2.26	<b>0.043</b>	0.175	0.191
ppm Water	ASTM D6304 >22600	<b>435</b>	1750.2	1917.7






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>▲ 68811</b>	▲ 217153	---
Particles >6µm	ASTM D7647 >2500	<b>▲ 20200</b>	▲ 140992	---
Particles >14µm	ASTM D7647 >320	<b>▲ 1131</b>	▲ 14784	---
Particles >21µm	ASTM D7647 >80	<b>▲ 214</b>	▲ 2691	---
Particles >38µm	ASTM D7647 >20	<b>1</b>	▲ 21	---
Particles >71µm	ASTM D7647 >4	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c) >20/18/15	<b>▲ 23/22/17</b>	▲ 25/24/21	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D974 0.04	<b>0.382</b>	0.111	0.073

# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	▲ MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	LIGHT	NONE
Debris	scalar	*Visual	NONE	NONE	▲ HEAVY ▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	97	101	99.5
Visc @ 100°C	cSt	ASTM D445	17.5	16.7	17.5
Viscosity Index (VI)	Scale	ASTM D2270	198	179	193

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO20000357  
**Lab Number** : 06141373  
**Unique Number** : 10966181  
**Test Package** : IND 2 ( Additional Tests: KV100, PrtCount, VI )

**IRON HORSE MIDSTREAM**  
 1419 COUNTY RD 1290  
 AMBER, OK  
 US 73004

**Received** : 08 Apr 2024  
**Tested** : 09 Apr 2024  
**Diagnosed** : 10 Apr 2024 - Angela Borella  
 Contact: MATT LIVELY  
 matt.lively@cardinalmidstream.com