


## **OIL ANALYSIS REPORT**

Sample Rating Trend



NORMAL



Machine Id

# **SULLAIR CMP 1009 - RJR (S/N 003-138998)**

Component Compressor

Fluid

PG-32 (35 GAL)

<b>D</b> 1		$\sim$	. 10	$\neg$	<b>71</b>	$\overline{}$
DI	А	(51	МÜ	D).	3 I	3
-1	, ,					

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0911584	WCI2289130	WC0652735
Sample Date		Client Info		05 Apr 2024	05 May 2023	15 Mar 2022
Machine Age	hrs	Client Info		77221	74295	71147
Oil Age	hrs	Client Info		1354	4300	1400
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	<1	<1
Aluminum	ppm	ASTM D5185m	>25	0	3	<1
Lead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	0	0	<1
Tin	ppm	ASTM D5185m	>15	<1	1	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m		363	385	406
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		0	<1	0
Calcium	ppm	ASTM D5185m		0	2	<1
Phosphorus	ppm	ASTM D5185m		0	3	5
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		555	545	487
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	<1
Sodium	ppm	ASTM D5185m		62	53	58
Potassium	ppm	ASTM D5185m	>20	2	4	3
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
A	1/0111	AOTA DOO		0.00	0.00	0.40

Acid Number (AN)

mg KOH/g ASTM D8045


0.32


0.32

0.16



### **OIL ANALYSIS REPORT**






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		44.3	45.4	43.8


SAMPLE IMAGES


Color


**Bottom** 















Certificate 12367

Report Id: AIRGREWC [WUSCAR] 06141385 (Generated: 04/10/2024 16:50:28) Rev: 1

Laboratory Sample No. Test Package : IND 2

: WC0911584 Lab Number : 06141385 Unique Number : 10966193

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Received **Tested** Diagnosed

: 08 Apr 2024 : 09 Apr 2024 : 10 Apr 2024 - Angela Borella

203 AERO COURT GREENSBORO, NC US 27409

Contact: Dallas Burcham

dallas.burcham@fs-compression.com T: (336)605-9622

**FS-COMPRESSION CO, LLC** 

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (336)605-9844

Contact/Location: Dallas Burcham - AIRGREWC