




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**QUINCY UN122271 - B/E AEROSPACE**

Component  
**Compressor**  
 Fluid  
**{not provided} (--- GAL)**

## DIAGNOSIS

**Recommendation**  
 Resample at the next service interval to monitor.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 There is no indication of any contamination in the oil.

**Fluid Condition**  
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0911601</b>	---	---
Sample Date	Client Info		<b>03 Apr 2024</b>	---	---
Machine Age	hrs Client Info		<b>14717</b>	---	---
Oil Age	hrs Client Info		<b>0</b>	---	---
Oil Changed	Client Info		<b>N/A</b>	---	---
Sample Status			<b>NORMAL</b>	---	---

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m	>50	<b>0</b>	---	---
Chromium	ppm ASTM D5185m	>10	<b>0</b>	---	---
Nickel	ppm ASTM D5185m		<b>0</b>	---	---
Titanium	ppm ASTM D5185m		<b>0</b>	---	---
Silver	ppm ASTM D5185m		<b>0</b>	---	---
Aluminum	ppm ASTM D5185m	>25	<b>0</b>	---	---
Lead	ppm ASTM D5185m	>25	<b>0</b>	---	---
Copper	ppm ASTM D5185m	>50	<b>0</b>	---	---
Tin	ppm ASTM D5185m	>15	<b>0</b>	---	---
Vanadium	ppm ASTM D5185m		<b>0</b>	---	---
Cadmium	ppm ASTM D5185m		<b>0</b>	---	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m		<b>0</b>	---	---
Barium	ppm ASTM D5185m		<b>0</b>	---	---
Molybdenum	ppm ASTM D5185m		<b>0</b>	---	---
Manganese	ppm ASTM D5185m		<b>0</b>	---	---
Magnesium	ppm ASTM D5185m		<b>0</b>	---	---
Calcium	ppm ASTM D5185m		<b>0</b>	---	---
Phosphorus	ppm ASTM D5185m		<b>10</b>	---	---
Zinc	ppm ASTM D5185m		<b>0</b>	---	---
Sulfur	ppm ASTM D5185m		<b>0</b>	---	---

## CONTAMINANTS



	method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m	>25	<b>0</b>	---	---
Sodium	ppm ASTM D5185m		<b>&lt;1</b>	---	---
Potassium	ppm ASTM D5185m	>20	<b>0</b>	---	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045		<b>0.33</b>	---	---





# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	---	---
Yellow Metal	scalar	*Visual	NONE	NONE	---	---
Precipitate	scalar	*Visual	NONE	NONE	---	---
Silt	scalar	*Visual	NONE	NONE	---	---
Debris	scalar	*Visual	NONE	NONE	---	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---	---
Appearance	scalar	*Visual	NORML	NORML	---	---
Odor	scalar	*Visual	NORML	NORML	---	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---	---
Free Water	scalar	*Visual		NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	50.0	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color				no image	no image
Bottom				no image	no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0911601      **Received** : 08 Apr 2024  
**Lab Number** : **06141392**      **Tested** : 09 Apr 2024  
**Unique Number** : 10966200      **Diagnosed** : 10 Apr 2024 - Angela Borella  
**Test Package** : IND 2

**FS-COMPRESSION CO, LLC**  
 203 AERO COURT  
 GREENSBORO, NC  
 US 27409  
 Contact: Dallas Burcham  
 dallas.burcham@fs-compression.com  
 T: (336)605-9622  
 F: (336)605-9844

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)