

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

QUINCY UN122272 - B/E AEROSPACE

Component Compressor

Fluid {not provided} (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0886203		
Sample Date		Client Info		03 Apr 2024		
Machine Age	hrs	Client Info		62212		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		9		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.27		



OIL ANALYSIS REPORT





	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	NONE			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
Apr3/24	Appearance	scalar	*Visual	NORML	NORML			
Ap	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.1	NEG			
	Free Water	scalar	*Visual		NEG			
	FLUID PROPER1	TIES	method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445		46.3			
	SAMPLE IMAGES	S	method	limit/base	current	history1	history2	
Apr3.24	Color					no image	no image	
	Bottom					no image	no image	
	2			Apr3/24				
	Non-ferrous Metal	S		Apr3/24				
	Viscosity @ 40°C				Acid Number			
	55			, 0.30				
	50 - Abnormal			HO 0.24				
	(C) 0+ 45			(b)H0,0,24 (b)H0,0,24 (c) 0,18 (c) 0,18	-			
	경 40 - Abnormal			4 0.12	1			
	35			0.06				
	Apr3/24			Apr3/24	Apr3/24			
	Apri			Apr	Apr			
		1 Madiso Recei Teste Diagr	ived : 08	, NC 27513 3 Apr 2024 9 Apr 2024 Apr 2024 - Ange	alo Porollo	FS-COMPRESSION CO, LI 203 AERO COUF GREENSBORO, N US 274 Contact: Dallas Burcha		

Report Id: AIRGREWC [WUSCAR] 06141393 (Generated: 04/10/2024 16:57:48) Rev: 1

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Dallas Burcham - AIRGREWC

F: (336)605-9844