

## **OIL ANALYSIS REPORT**

Sample Rating Trend

### NORMAL

#### Area NOT GIVEN Machine Id INGERSOLL RAND CBV829509

Component Compressor

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.


#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06141436		
Sample Date		Client Info		26 Mar 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.8	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	0		
Barium	ppm	ASTM D5185m	525	571		
Molybdenum	ppm	ASTM D5185m	10	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	5	0		
Calcium	ppm	ASTM D5185m	10	0		
Phosphorus	ppm	ASTM D5185m	250	0		
Zinc	ppm	ASTM D5185m	100	5		
Sulfur	ppm	ASTM D5185m	400	344		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		36		
Potassium	ppm	ASTM D5185m	>20	3		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.077		



# **OIL ANALYSIS REPORT**



Certificate L2367	Laboratory Sample No. Lab Number Unique Number Test Package	: 10966244	ived : 08 ed : 09	42/92289 7, NC 27513 8 Apr 2024 9 Apr 2024 Apr 2024 - Ange	ela Borella	JOHN HENRY FOSTER COMPANY 4700 LEBOURGET STREET SAINT LOUIS, MO US 63134 Contact: RACHEL VON HATTEN		
		Base 45 45 40			0.08 0.00 0.00 0.00 0.00 0.00 V 0.00 V V 0.00 V V 0.00 V V 0.00 V V 0.00 V V V V	24		24
		Uiscosity @ 40°C	C		( <sup>0</sup> )	Acid Number		
		Non-ferrous Met	als					
		udd 4			Mar26/24			
		GRAPHS Ferrous Alloys						
	M	Bottom					no image	no image
	Mar26/24 +	SAMPLE IMAGE	ES	method	limit/base	current	history1 no image	history2 no image
		Visc @ 40°C	cSt	ASTM D445	46	52.6		
		FLUID PROPER		method	limit/base	current	history1	history2
		Emulsified Water Free Water	scalar scalar	*Visual *Visual	>0.8	NEG NEG		
	Mar26/24	Odor	scalar	*Visual	NORML	NORML		
	6/24 -	Appearance	scalar	*Visual	NORML	NORML		
		Debris Sand/Dirt	scalar scalar	*Visual *Visual	NONE NONE	NONE		
		Silt	scalar	*Visual	NONE	NONE		
		Precipitate	scalar	*Visual	NONE	NONE		
		Yellow Metal	scalar	*Visual	NONE	NONE		

Report Id: UCJOHSAI [WUSCAR] 06141436 (Generated: 04/10/2024 17:21:50) Rev: 1

Ē

Contact/Location: RACHEL VON HATTEN - UCJOHSAI

Page 2 of 2