

OIL ANALYSIS REPORT

Area NOT GIVEN Machine Id INGERSOLL RAND MOX1006282 - PLAZE Component

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



Sample Rating Trend




NORMAL

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06141455		
Sample Date		Client Info		01 Mar 2024		
Machine Age	hrs	Client Info		7112		
Oil Age	hrs	Client Info		7112		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		65		
Phosphorus	ppm	ASTM D5185m		241		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		498		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		12		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.24		



OIL ANALYSIS REPORT

VISUAL



	VISUAL		method		current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Mar1/24	Appearance	scalar	*Visual	NORML	NORML		
N N N N N N N N N N N N N N N N N N N	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPERT		mothod	limit/base	ourropt	biotory1	history ()
	Visc @ 40°C	cSt	method ASTM D445		current 54.4	history1	history2
					04.4		
	SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Mar1/24	Color					no image	no image
	Bottom				A.	no image	no image
	GRAPHS Ferrous Alloys	5		Mar1/24			
	Viscosity @ 40°C			Mar(124 0.20 0.0 Verid 0.0 Verid 0.0 Verid 0.0 Verid 0.0 Verid 0.0 Verid 0.0 Verid 0.0 Verid 0.0 Verid)		
Laboratory Sample No. Lab Number Unique Number Test Package Viscuss this sample report,	*//www : WearCheck USA - 501 : UCH06141455 : 06141455 : 10966263 : IND 2	Recei Teste Diagr	ived : 08 ed : 09 nosed : 10	, NC 27513 3 Apr 2024 9 Apr 2024 Apr 2024 - Ange	JOH!	N HENRY FOST 4700 LEBOUF SAII ontact: RACHEL rvonh	RGET STREE NT LOUIS, MO US 6313

Report Id: UCJOHSAI [WUSCAR] 06141455 (Generated: 04/10/2024 17:28:44) Rev: 1

P

Contact/Location: RACHEL VON HATTEN - UCJOHSAI