

## **OIL ANALYSIS REPORT**

Sample Rating Trend

NORMAL

### Area XTEND [417482] QUINCY APFS5118302 - SIKA

Component Compressor

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the component.


#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	<b>/IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06141494		
Sample Date		Client Info		07 Apr 2024		
Machine Age	hrs	Client Info		20678		
Oil Age	hrs	Client Info		6246		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	6		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.14	0.46		



# **OIL ANALYSIS REPORT**





	VISUAL						TIIStoryz
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
1	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Apr7/24 -	Appearance	scalar	*Visual	NORML	NORML		
Apr	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPER		mothod	limit/base	current	history1	history?
	Visc @ 40°C	cSt	method ASTM D445	46	51.3	Thistory I	history2
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Ap7/24 +	Color				And a second of a	no image	no image
	Bottom					no image	no image
	udd 4			Apr7/24			
	Non-ferrous Meta	ls		Aprī/24			
	Viscosity @ 40°C				Acid Number		
	Abnormal Base 40 40 40 40 40 40 40 40 40 40 40 40 40			(0,0.50 (0,0.40 (0,0.40 (0,0.40 (0,0.40 (0,0.40 (0,0.40)	Base		
Laboratory Sample No.	WearCheck USA - 501 Madison Ave., Cary, NC 27513 AIRMATIC COMPRESSOR SYS UCH06141494 Received : 08 Apr 2024 700 WASHINGTON : 06141494 Tested : 09 Apr 2024 CARLSTAE : 10966302 Diagnosed : 10 Apr 2024 - Angela Borella US : IND 2 Contact: ELVIN						

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCAIRCAR [WUSCAR] 06141494 (Generated: 04/10/2024 17:54:06) Rev: 1

50

Contact/Location: ELVIN DIAZ - UCAIRCAR

F: (201)342-6241