






OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | --- |
| Yellow Metal | scalar | *Visual | NONE | NONE | --- |
| Precipitate | scalar | *Visual | NONE | NONE | --- |
| Silt | scalar | *Visual | NONE | NONE | --- |
| Debris | scalar | *Visual | NONE | NONE | --- |
| Sand/Dirt | scalar | *Visual | NONE | NONE | --- |
| Appearance | scalar | *Visual | NORML | NORML | --- |
| Odor | scalar | *Visual | NORML | NORML | --- |
| Emulsified Water | scalar | *Visual | NEG | --- | --- |
| Free Water | scalar | *Visual | NEG | --- | --- |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|----------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 46.37 | --- | --- |
| Visc @ 100°C | cSt | ASTM D445 | 7.44 | --- | --- |
| Viscosity Index (VI) | Scale | ASTM D2270 | 124 | --- | --- |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

| | | | |
|--------|--|----------|----------|
| Color | | no image | no image |
| Bottom | | no image | no image |

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : FCH0000024 **Received** : 08 Apr 2024
Lab Number : 06141869 **Tested** : 10 Apr 2024
Unique Number : 10966677 **Diagnosed** : 10 Apr 2024 - Doug Bogart
Test Package : PLANT (Additional Tests: FT-IR, KV100, VI)

DANA - FAIRFIELD CUSTOM GEARS AND DRIVES
 2400 SAGAMORE PKWY S #2400
 LAFAYETTE, IN
 US 47905
 Contact: Service Manager
 Jeffrey.Alexander@fuchs.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)