

## **OIL ANALYSIS REPORT**

# **KAESER SM 10 AIRCENTER 5483**

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

## DIAGNOSIS

Compressor

Machine Id

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

## Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

3144 (S/N 2	127)					
		Feb2019	Sep2019 Jun2020	Dec2021 Oct2022	Dec2023	
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA011911	KCP46929D	KCP43753
Sample Date		Client Info		26 Dec 2023	13 Oct 2022	29 Dec 2021
lachine Age	hrs	Client Info		27529	22845	19447
Dil Age	hrs	Client Info		0	3398	3000
Dil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				NORMAL	SEVERE	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
on	ppm	ASTM D5185m	>50	0	12	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
lickel	ppm	ASTM D5185m	>3	0	<1	0
ītanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	1
Aluminum	ppm	ASTM D5185m	>10	2	0	0
ead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	17	33	17
īn	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m				0
/anadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	<1	0	0
Nolybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	2	9	<1
Calcium	ppm	ASTM D5185m	2	4	0	0
Phosphorus	ppm	ASTM D5185m		2	37	25
Zinc	ppm	ASTM D5185m		2	45	0
Sulfur	ppm	ASTM D5185m		18849	20675	18291
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	1
Sodium	ppm	ASTM D5185m		0	2	0
otassium	ppm	ASTM D5185m	>20	2	0	<1
Vater	%	ASTM D6304	>0.05	0.005	▲ 8.58	0.002
opm Water	ppm	ASTM D6304	>500	53	▲ 85800	18.6
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3502		7123
· Particles >6μm		ASTM D7647	>1300	1018		▲ 3993
- Particles >14μm		ASTM D7647	>80	53		<b>A</b> 733
•			>20	10		<b>1</b> 97
Particles >21µm		ASTM D7647				
•		ASTM D7647 ASTM D7647	>4	1		<b>1</b> 6
Particles >38µm			>4	1		▲ 16 0
Particles >38μm Particles >71μm		ASTM D7647	>4			
Particles >21µm Particles >38µm Particles >71µm Dil Cleanliness FLUID DEGRADA	TION _	ASTM D7647 ASTM D7647	>4 >3	1 19/17/13		0

Sample Rating Trend


NORMAL


Report Id: MASPAL [WUSCAR] 06142220 (Generated: 04/11/2024 11:33:27) Rev: 1


0.33 0.30 0.28 Contact/Location: BILLY MASDON - MASPAL




# **OIL ANALYSIS REPORT**







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	🔺 MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	- HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	▲ 0.2%	NEG
Free Water	scalar	*Visual		NEG	▲ >10%	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	45.1	44.1	44.5
SAMPLE IMAGES	\$	method	limit/base	current	history1	history2
Color						
Bottom						



11

0

Feb11/19

Sep 9/19

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Report Id: MASPAL [WUSCAR] 06142220 (Generated: 04/11/2024 11:33:27) Rev: 1

Jec29/2

Certificate 12367

Contact/Location: BILLY MASDON - MASPAL

Т:

F:

Contact: BILLY MASDON

billy.masdon@masdoncabinets.com