




# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**KAESER SK 15 AC 6399576 (S/N 1025)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of visible silt present in the sample. Moderate concentration of visible dirt/debris present in the oil. There is a moderate concentration of water present in the oil. Excessive free water present.

### Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KCPA016846</b>	KCP43490	KCP32537
Sample Date	Client Info			<b>01 Apr 2024</b>	28 Dec 2021	26 Jan 2021
Machine Age	hrs	Client Info		<b>8197</b>	5465	4363
Oil Age	hrs	Client Info		<b>1300</b>	1100	2300
Oil Changed	Client Info			<b>Not Chngd</b>	Changed	N/A
Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	2
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	8	<1	2
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m		---	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0




ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	13
Barium	ppm	ASTM D5185m	90	1	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	100	16	55	48
Calcium	ppm	ASTM D5185m	0	5	<1	<1
Phosphorus	ppm	ASTM D5185m	0	2	2	4
Zinc	ppm	ASTM D5185m	0	10	8	12
Sulfur	ppm	ASTM D5185m	23500	13888	19224	17211

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		<1	15	12
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304	>0.05	▲ 0.511	0.018	0.033
ppm Water	ppm	ASTM D6304	>500	▲ 5110	182.2	337.3

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		---	20661	16549
Particles >6µm		ASTM D7647	>1300	---	▲ 7300	▲ 6458
Particles >14µm		ASTM D7647	>80	---	▲ 179	▲ 279
Particles >21µm		ASTM D7647	>20	---	▲ 32	▲ 53
Particles >38µm		ASTM D7647	>4	---	2	▲ 5
Particles >71µm		ASTM D7647	>3	---	0	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	---	▲ 20/15	▲ 20/15

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.39	0.336	0.391


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	▲ HEAVY	NONE	NONE
Debris	scalar	*Visual	▲ MODER	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	▲ 0.2%	NEG	NEG
Free Water	scalar	*Visual	● 5.0	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	46.3	45.5	47.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA016846 **Received** : 08 Apr 2024  
**Lab Number** : 06142239 **Tested** : 11 Apr 2024  
**Unique Number** : 10967047 **Diagnosed** : 11 Apr 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**TRUCK CENTERS**  
 720 N SERVICE RED  
 FORISTELL, MO  
 US 63348

Contact: D. PENNINGTON  
 dpennington@truckcentersinc.com

T:  
 F: