


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER SK 15 8700404 (S/N 2018)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Nov2023	Mar2024		
SAMPLE INFORM	AATION.	mathad	limit/bass	ourrent.	historyd	hiotom/2
	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121604	KC122907	
Sample Date		Client Info		18 Mar 2024	28 Nov 2023	
Machine Age	hrs	Client Info		3247	1792	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	
Chromium	ppm	ASTM D5185m	>10	<1	<1	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	2	2	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	5	9	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	9	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	52	23	
Calcium	ppm	ASTM D5185m	2	4	<1	
Phosphorus	ppm	ASTM D5185m		0	32	
Zinc	ppm	ASTM D5185m		19	19	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	
Sodium	ppm	ASTM D5185m		6	5	
Potassium	ppm	ASTM D5185m	>20	5	6	
Water	%	ASTM D6304	>0.05	0.023	0.114	
ppm Water	ppm	ASTM D6304	>500	239	<u>▲</u> 1140	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1422		
Particles >6µm		ASTM D7647	>1300	420		
Particles >14µm		ASTM D7647	>80	30		
Particles >21µm		ASTM D7647	>20	8		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12		
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.28

0.36



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No.

: KC121604 Lab Number : 06142295 Unique Number : 10967103 Test Package : IND 2

Received : 08 Apr 2024 **Tested** : 09 Apr 2024 Diagnosed

: 11 Apr 2024 - Don Baldridge

**ALBRECHT CABINETS** 1350 GLOBAL CT.

SARASOTA, FL US 34240 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: