


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AS 20T 3103203 (S/N 1368)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Feb 2018	Aug2019 Jun2020	Apr2021 Feb2022 Apr2023	Apr2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA015097	KCP53585	KCP41163
Sample Date		Client Info		01 Apr 2024	04 Apr 2023	22 Feb 2022
Machine Age	hrs	Client Info		56081	52325	47958
Oil Age	hrs	Client Info		3756	0	4100
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ATTENTION	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	6	11	6
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	3	0	5
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	100	27	0	37
Calcium	ppm	ASTM D5185m	0	4	0	0
Phosphorus	ppm	ASTM D5185m	0	<1	0	4
Zinc	ppm	ASTM D5185m	0	26	0	5
Sulfur	ppm	ASTM D5185m	23500	21544	24403	16693
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		14	5	20
Potassium	ppm	ASTM D5185m	>20	4	0	4
Water	%	ASTM D6304	>0.05	0.010	0.005	0.005
ppm Water	ppm	ASTM D6304	>500	109	53.5	58.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		10987	5281	6128
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2937	1821	1424
Particles >14µm		ASTM D7647	>80	<u> </u>	103	1 09
Particles >21µm		ASTM D7647	>20	△ 53	20	32
Particles >38µm		ASTM D7647	>4	1	0	2
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/19/15	20/18/14	18/14
FLUID DEGRADA	MOITA	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: KCPA015097 Lab Number : 06142309 Unique Number: 10967117

Received **Tested** Diagnosed

: 08 Apr 2024 : 09 Apr 2024 : 10 Apr 2024 - Doug Bogart

CODI MFG 14352 W 44TH AVE GOLDEN, CO US 80403 Contact: Service Manager

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: